



भारत सरकार **Government of India** विदयुत मंत्रालय **Ministry of Power** केन्द्रीय विद्युत प्राधिकरण **Central Electricity Authority** विद्युत संचार विकास प्रभाग

Power Communication Development Division

CEA Case No.: RAJ-698

PTCC proposal of 220 kV S/C transmission line (21 km on DC tower and 2 km on MC tower) from 320 MW solar power project of Avaada Energy Private Limited in Kolayat Tehsil, Bikaner to Bhadla-II PS (23 km)

| Reference: | | Dated | |
|------------|---|------------|--|
| S. No. | Reference No. | 09.02.2022 | |
| (i) | M/s Avaada Energy Pvt Ltd: AEPL/320 MW/BHADLA-II/ | 07.02.2022 | |
| (-) | GEA DECC/00022022 /01 | 01.04.0000 | |
| | BSNL: DET/PTCC/ND/DV-10068/UP-1374/2022-2023/ | 21.04.2022 | |
| (ii) | BSNL: DET/T TCC/ND/DV 159/NIWP/PTCC/883 | 03.03.2022 | |
| (iii) | North Western Railway: SG/158/NWR/PTCC/883 | 06.04.2022 | |
| (iv) | Defense: B/46937/Sigs 7(b)/2776 | 00.0 | |

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide above reference (ii) has intimated that there are no BSNL lines (copper cable and armored OFC) in the route of the proposed power line and conveyed its NOC. The LF induction on block & telecom circuits of North Western Railway with respect to details furnished vide above reference (iii) has been computed. The voltages likely to be induced on paralleling block & telecom circuits of North Western Railway under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors, as applicable, have been considered. The Defence Authority, vide above reference (iv) have issued No Objection Certificate (NOC).


Taking above into consideration, necessary action regarding issuance of PTCC route approval may be taken.

Encl.: As above.

| 1. | Engineer (PTCC), | BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001. | Only covering |
|----|------------------|---|--------------------|
| ' | Northern Zone | Delmi 110001. Della Pellerary Head Quarter Office. | 77.7144 |
| 2. | Dv CSTE | North Western Railway, Head Quarter Office, Room no. 136, First Floor, Near Jawahar Circle, | With Annexure-I |
| | | Jaipur – 302017 Fraggy Pyt Ltd. 910/19. | E bind |

M/s Avaada Energy Pvt Ltd, 910/19, For kind Sr. VP Suryakiran, Kasturba Gandhi Marg, New Delhi information (Evacuation 3. -110001 System)

File No.CEA-PS-17-11(11)/25/2022-PCD Division / 398



भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण **Central Electricity Authority** विद्युत संचार विकास प्रभाग

Power Communication Development Division

के.वि.प्रा. केस सं. : RAJ-698

पी.टी.सी. प्रस्ताव 220 kV S/C transmission line (21 km on DC tower and 2 km on MC tower) from 320 MW solar power project of Avaada Energy Private Limited in Kolayat Tehsil, Bikaner to Bhadla-II PS (23 km)

| सन्दर्भ: | | |
|-------------|--|-------------|
| क्रमांक | सन्दर्भ सं. | T&: |
| (i) | M/s Ayanda Engrave Dest I at A EDY 1999 | दिनांक |
| | M/s Avaada Energy Pvt Ltd: AEPL/320 MW/BHADLA-II/ CEA/PTCC/09022022 /01 | 09.02.2022 |
| (ii) | BSNL: DET/PTCC/ND/DV-10068/UP-1374/2022-2023/ | 21 04 5 5 5 |
| (iii) | North Western Railway: SG/158/NWR/PTCC/883 | 21.04.2022 |
| (iv) | Defense: B/46937/Sigs 7(b)/2776 | 03.03.2022 |
| | 1 Dolotto D/4073 // Sigs /(0)/2//6 | 06.04.2022 |

संदर्भ (i) द्वारा प्रस्तुत पीटीसीसी प्रस्ताव की जांच की गई है। बीएसएनएल ने उपरोक्त सन्दर्भ (ii) के द्वारा अवगत कराया है कि पाँवर लाइन के परिधि में कोई बीएसएनएल लाइन नहीं है तथा अनापत्ति प्रमाण पत्र जारी किया है। उत्तर पश्चिम रेल के ब्लॉक एवं टेलिकॉम सर्किटों पर निम्न आवृत्ति प्रेरण गणना उपरोक्त संदर्भ (iii) में दिए गए विवरणों के संबंध में की गई है। सिंगल लाइन टू ग्राउंड फाल्ट अवस्था में उत्तर पश्चिम रेल के ब्लॉक एवं टेलिकॉम सर्किटों पर प्रेरित वोल्टेज अनुलग्नक –। में संलग्न है। स्क्रीनिंग कारक का मान यथानुरूप लिया गया है। रक्षा प्राधिकरण ने उपरोक्त सन्दर्भ (iv) के द्वारा अनापत्ति प्रमाण पत्र जारी किया है। उपरोक्त को ध्यान में रखते हुए, पीटीसीसी मार्ग अनुमोदन जारी करने के संबंध में आवश्यक कार्रवाई

की जाए।

संलग्नः ऊपरोक्त अनुसार

T۵

| 10, | | | |
|-----|---|---|----------------------|
| 1. | Divisional Engineer (PTCC), Northern Zone | BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001. | Only covering |
| 2. | Dy. CSTE | North Western Railway, Head Quarter Office, Room no. 136, First Floor, Near Jawahar Circle, Jaipur – 302017 | With Annexure-I |
| 3. | Sr. VP (Evacuation System) | M/s Avaada Energy Pvt Ltd, 910/19, Suryakiran, Kasturba Gandhi Marg, New Delhi - 110001 | For kind information |

ANNEXURE - I CEA Case No.: RAJ-698 Map Scale : 1 cm=500 m Name of the Power line: 220 kV S/C transmission line (21 km on Total Length: 23 km DC tower and 2 km on MC tower) from 320 MW solar power S.R. Value: $25,000 \Omega$ -cm project of Avaada Energy Private Limited in Kolayat Tehsil, Bikaner to Bhadla-II PS Effective I.V Fault Mutual Length of in current Parallelism Coupling Volts. in Amps. in Ohms. in Km. Telecom. Details S.No.

| | | f. No: SG/158/NW s & Telecom Circu | | ated: 03.03.202 | 2 |
|---|---------------|---------------------------------------|--------|-----------------|----|
| 1 | Bap - Sird | 2.25 | 0.0021 | 10000 | 21 |
| | * | 16.2 | 0.0031 | 10000 | 31 |
| 2 | Sird - Nokhra | 16.2 | 0.0031 | 10000 | |

Rated

प्रतिक श्रीवार्त्यः PRATEEK SRian सहायक निर्मान-11/Assin, Director-11 केन्द्रीय विधान प्रतिकारण/C.E.A. किन्द्रीय विधान प्रतिकारण/C.E.A. विश्वन मंत्रालयं/Ministry of Power पारत सरवार /Govd. of India मार सरवार /Govd. of India मार किल्ली/Made Beith