



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
केन्द्रीय विद्युत प्राधिकरण  
Central Electricity Authority  
विद्युत संचार विकास प्रभाग  
Power Communication Development Division  
\*\*\*\*\*

CEA Case No.: UP-591/417-418  
PTCC proposal for LILO of 220 kV Greater Noida (765 kV) (Jehangirpur) to IITGNL line at 220 kV Jewar S/S : 6.905 km

Reference:		
S. No.	Reference No.	Dated
(i)	UPPTCL: 239/ETD-II/Noida/PTCC	14.02.2022
(ii)	BSNL: DET/PTCC/ND/DV-10057/UP-1039/2022-23	12.04.2022
(iii)	North Central Railway: NCR/S&T/2074/telecom/PTCC(part-I)	01.04.2022
(iv)	Defense: B/46937/Sigs 7(b)/2807	06.04.2022

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide above reference (ii) has intimated that no BSNL lines (Copper cable and armoured OFC) in the route of proposed power line and has conveyed its NOC. North Central Railway vide above reference (iii) has conveyed that there are no railway signaling and telecom circuits within the corridor of 8 km of the proposed power line. Hence, IV Calculations are not required for BSNL and North Central Railway. Vide reference (iv) above, The Defence Authority have issued No Objection Certificate (NOC).

Taking above into consideration, necessary action regarding issuance of PTCC route approval may be taken.

राधेन्द्र गुप्ता सिंह  
Director 26.05.2022

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi-110001.	
2.	Executive Engineer	UPPTCL; O/o Executive Engineer, Electricity Transmission Division-II, 220 kV Sub Station Sec-20, Noida.	Copy for information



75  
आज़ादी का  
अमृत महोत्सव

भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
केन्द्रीय विद्युत प्राधिकरण  
Central Electricity Authority  
विद्युत संचार विकास प्रभाग  
Power Communication Development Division  
\*\*\*\*\*

के.वि.प्रा. केस सं.: UP-591
पी.टी.सी.सी. प्रस्ताव LILO of 220 kV Greater Noida ( 765 kV) (Jehangirpur) to IITGNL line at 220 kV Jewar S/S : 6.905 km

क्रमांक	सन्दर्भ सं.	दिनांक
(i)	UPPTCL: 239/ETD-II/Noida/PTCC	14.02.2022
(ii)	BSNL: DET/PTCC/ND/DV-10057/UP-1039/2022-23	12.04.2022
(iii)	North Central Railway: NCR/S&T/2074/telcom/PTCC(part-I)	01.04.2022
(iv)	Defense : B/46937/Sigs 7(b)/2807	06.04.2022

संदर्भ (i) द्वारा प्रस्तुत पीटीसीसी प्रस्ताव की जांच की गई है। बीएसएनएल ने उपरोक्त संदर्भ (ii) के माध्यम से सूचित किया है कि प्रस्तावित बिजली लाइन के मार्ग में कोई बीएसएनएल लाइन (कॉपर केबल और आर्मर्ड ओएफसी) नहीं है और एनओसी से अवगत करा दिया है। उत्तर मध्य रेलवे ने उपरोक्त संदर्भ (iii) के माध्यम से सूचित किया है कि प्रस्तावित बिजली लाइन के 8 किमी के गलियारे के भीतर कोई रेलवे सिग्नलिंग और दूरसंचार सर्किट नहीं है। इसलिए, बीएसएनएल और उत्तर मध्य रेलवे के लिए IV गणनाओं की आवश्यकता नहीं है। उपरोक्त संदर्भ (iv) के तहत, रक्षा प्राधिकरण ने अनापत्ति प्रमाणपत्र (एनओसी) जारी किया है। उपरोक्त को ध्यान में रखते हुए, पीटीसीसी मार्ग अनुमोदन जारी करने के संबंध में आवश्यक कार्रवाई की जाए।

मधुवेन्दु प्रताप सिंह  
निदेशक 26.05.2022

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi-110001.	
2.	Executive Engineer	UPPTCL; O/o Executive Engineer, Electricity Transmission Division-II, 220 kV Sub Station Sec-20, Noida.	जानकारी हेतु