

I/17357/2021



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

Case No. : RAJ-673
PTCC proposal of 220 kV S/C transmission line from 220/33 kV PSS Renew Solar Energy (Jharkhand Three) Pvt. Ltd. to 765/400/220 kV GSS PGCIL Fatehgarh-II (20.30 km)

Reference:		
S. No.	Reference No.	Dated
(i)	M/s Renew Solar Energy (Jharkhand Three) Pvt. Ltd.: Renew/ SECI-4/PTCC/01	17.06.2021
(ii)	BSNL: DET/PTCC/ND/DV-9916/Raj-1322/2021-2022	22.07.2021
(iii)	North Western Railway: SG/158/NWR/PTCC/830	14.07.2021
(iv)	M/s Renew Solar Energy (Jharkhand Three) Pvt. Ltd.: Renew/ SECI-4/RAJ/09	02.08.2021

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide reference (ii) has intimated that there are no BSNL lines (copper cable and armored OFC) in the route of the proposed power line and has conveyed its NOC. North Western Railway vide reference (iii) has intimated that there is no railway line appearing/existing in the route of the proposed power line. Hence, IV calculation for BSNL and North Western Railway is not required.

Telecommunication details from Defense are pending and the power authority has shown urgency for charging the line vide above reference (iv). In view of this, necessary action regarding issuance of **provisional PTCC route approval for 220 kV S/C transmission line from 220/33 kV PSS Renew Solar Energy (Jharkhand Three) Pvt. Ltd. to 765/400/220 kV GSS PGCIL Fatehgarh-II** may be taken.

Director

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001.	
2.	M/s Renew Solar Energy (Jharkhand Three) Pvt. Ltd.	ReNew Hub, Commercial Block-1, Zone-6, Golf Course Road, DLF City Phase-V, Gurugram-122009.	Copy for information