





# भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत संचार विकास प्रभाग

## **Power Communication Development Division**

\*\*\*\*\*

CEA Case No.: MP-490					
PTCC ap	PTCC approval for 220 kV DCSS line from 220 kV Nipaniya S/S for power supply of 54.5				
MVA to pump house of Shamgarh-Suwasara irrigation project of SSPIURegd.					
S. No	Reference No.	Dated			
(i)	MPPTCL: 04-02/PTCC/2668/PS/2559	10.11.2021			
(ii)	MPPTCL: e-mail.	02.11.2022			
(iii)	MPPTCL: e-mail	12.12.2022			
(iv)	BSNL: PTCC/WR/2021-2022/MP-730	14.06.2022			
(v)	West Central Railway: WCR/N-HQ/120PTCC-CORR-T-50-PT-	23.11.2021			
	IIICase-325				
(vi)	Defense: B/46937/ Sigs 7(b)/2657	09.12.2021			

The PTCC proposal submitted vide reference (i), (ii) & (iii) has been examined. The LF induction on telecom circuits of BSNL with respect to details furnished vide above references (iv) has been computed. The voltages likely to be induced on paralleling telecom circuits of BSNL under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors, as applicable, have been considered. Vide reference (v) & (vi) above, GM (S&T), West Central Railway and DG Signals, MoD, respectively, have issued No Objection Certificate (NOC).

EPR zone for new 220/11 kV S/s at Kilgari village, Shamgarh is mentioned below:

Voltage Leve	l(v)	430	650	7000	10000	
EPR Zone (m	1)	1109	712	9	N.A	

Taking above into consideration, necessary action regarding issuance of PTCC route approval may be taken.

Encl.: As above

### **Chief Engineer**

#### To,

1.	Div. Engr.(PTCC)	'D' Wing, III floor, Administrative Bldg.,	
	Western Zone	Telecom Complex, Juhu Tara Road Santa Cruz (West), Mumbai	
2.	Chief Engineer (Plg.&Design)-MPPTCL	Block No.3 Shakti Bhawan, Rampur Jabalpur- M.P	Copy for information

#### **ANNEXURE-I**

CEA Case No.: MP-490  Name of the Power line: 220 kV DCSS line from 220 kV Nipaniya S/S for power supply of 54.5 MVA to pump house of Shamgarh-Suwasara irrigation project of SSPIU.			Map Scale : 1 cm= 500 m  Total Length : 14.8 km  S.R. Value : 10000 Ohm-cm					
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.			
BSNL I	BSNL Letter No: BSNL: PTCC/WR/2021-2022/MP-730 Date: 14.06.2022							
	Affected Telecom Circuits Details							
1	Melkheda Exchange to village 0.45 0.0038 26622		101					
2	Chandwasa Exchange to village	0.2	0.0008	15752	13			