File No.CEA-PS-17-11(12)/64/2022-PCD Division







भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत संचार विकास प्रभाग Power Communication Development Division

PTCC approval for 220 kV transmission line modification for providing required clearances to upcoming NHSRCL (Bullet train) project at village Maan, Boisar: 220 kV D/C (BOI-DHN & BOI-VSV ckt) transmission line - regd.			
S. No	Reference No.	Dated	
(i)	AEML: AEML-MT/PROJECTS/STG/03/2022-23	10.06.2022	
(ii)	Western Railway: SG.158/28/09/326	26.07.2022	
	Defense D/40027/6: 7/1->/2002	24.08.2022	
(iii)	Defense: B/46937/Sigs 7(b)/2962	2110012022	

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on communication circuits of Western Railway and BSNL with respect to details furnished vide above reference (ii) and (iv) respectively have been computed. The voltage likely to be induced on paralleling communication circuits of UG cables of BSNL and Western Railway under Single Line to Ground fault condition are enclosed at Annexure-I and Annexure-II respectively. The screening factors as applicable have been considered. Vide reference (iii) above, DG Signals, MoD has issued No Objection Certificate (NOC) (enclosed as Annexure-III).

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office. Encl.: As above

Chief Engineer

1.	Divisional Engineer (PTCC), Western Zone	QA & Inspection circle, 1 st floor, D- wing, BSNL Admin Bldg., Junu Tara Road, Santacruz (West), Mumbai- 400054	
2.	GM (S&T) Western Railway	Office of PCSTE, S&T Dept., 5 th floor, Station Buillding, Churchgate, Mumbai – 400 020	With a request to henceforth, forward details of railway block and communication circuit along with route map for IV calculation <i>to this office</i> with a copy marked to concerned DET PTCC.
3.	DGM (Projects), AEML	Adani Electricity Management Institute, Opp SEEPZ Gate No. 3, Jogeshwari Vikhroholi link road, Goregaon (E), Mumbai 400 065	Copy for information.

To,

एनआरपीसी परिसर, कटवारिया सराय, नई दिल्ली-110016 टेलीफ़ोन: 011-26565214 ईमेल: cepcd.cea@gov.in वेबसाइट: www.cea.nic.in

NRPC Complex, Katwaria Sarai, New Delhi-110016 Telephone: 011-26565214 Email: cepcd.cea@gov.in Website: www.cea.nic.in

ANNEXURE-I

Name of providinat villag	ase No.: MRA-1206 of the Power line: 220 kV transmission line mod og required clearances to upcoming NHSRCL (Bullet ge Maan, Boisar: 220 kV D/C (BOI-DHN & Bo ssion line	train) project	Map Scale Total Length S.R. Value	: 1 cm= 500 m a : 1.34 km : 30000 Ohm-cm	
S.No.	Telecom. Details	Length of Parallelis m in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
	BSNL Letter No: IC/MBI/PTC Affected Blocks & Tele			.2022	
	Tarapur Telephone Exchange (MIDC)				
1	Exchange to Saroli Pillar	Out of parallelism			
2	Exchange to Tarapur Village Kurgaon				
3	Exchange to BARC Taps Colony Gate				
4	Exchange to Mahindra Park				

ANNEXURE-II

CEA Case No.: MRA-1206 Name of the Power line : 220 kV transmission line modification for providing required clearances to upcoming NHSRCL (Bullet train) project at village Maan, Boisar: 220 kV D/C (BOI-DHN & BOI-VSV ckt) transmission line			Map Scale : 1 cm= 500 m Total Length : 1.34 km S.R. Value : 30000 Ohm-cm		
S.No.	Telecom. Details	Length of Parallelis m in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
	WESTERN RAILWAY Letter No:	SG.158/28/0	9/326 Date: 26.0)7.2022	
	Affected Blocks & Tele	ecom Circuit	s Details		
1	Palghar - Umroli	0		0	
2	Umroli - Boisar		Out of parallelism		
3	Boisar - Vangaon	1			
4	Vangaon – Dahanu Road	0			

I/25358/2022 Te

Tele : 23019746

2-PCD DIVISION Directorate General of Signals Signals 7 General Staff Branch Integrated HQ of MoD (Army) DHQ PO, New Delhi - 110011

B/46937/Sigs 7(b)/2962/

Aug 2022

Dy. General Manager (Projects) Adani Electricity Mumbai Ltd. (Formerly Reliance Electric Generation & Supply Ltd) Adani Electricity Management Institute Opp. SEEPZ Gate No. 3, Jogeshwari Vikhroli Link Road Goregaon (E), Mumbai-400065, Maharashtra, India

PTCC CLEARANCE FOR DIVERSION/MODIFICATION OF PORTION OF EXISTING DOUBLE CIRCUIT 220KV BOISAR TIE LINE (BTL) TO PROVIDE REQUIRED ELECTRICAL CLEARANCE TO THE UPCOMING NHSRCL ROUTE AT BOISAR AREA

1. Refer your letter No AEML-MT/PROJECTS/STG/03/2022-23 dt 10 Jun 2022 (copy att).

2. No Objection Certificate (NOC) is accorded based on inputs provided as per Map sheets received vide your letter mentioned above.

3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(PS Samval) Col GSO 1 (Comn) for ADG T

Enclosures : As above

Copy to :-

The Director (PTCC), CEA Power Communication Development Division NRPC Complex, 18-A Shaheed Jeet Singh Marg Katwaria Sarai, New Delhi – 110016

The DET(PTCC), Northern Zone O/o PGM (North), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath New Delhi-110001 - for information

Sh Projeck

