





भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत संचार विकास प्रभाग

Power Communication Development Division

CEA Case No.: KNK-1005					
PTCC approval for 220 kV DC LILO line on MC towers from existing 220 kV RTPS – Sedam DC line to the proposed 220/110 kV Ram Samudra SS (9.335 km)- regd.					
S. No	Reference No.	Dated			
(i)	KPTCL: CEE/SLDC/PTCC/F-3420/3297-3305	07.07.2022			
(ii)	KPTCL: CEE/SLDC/PTCC/F-3420/9837-39	08.03.2023			
(iii)	KPTCL: E-mail	15.03.2023			
(iv)	BSNL: SR-PTCC/SKT 4128/3	05.12.2022			
(v)	South Central Railway: SG.85/4/3/PTCC/SCR/2022-23/KS-5 RC	05.09.2022			
(vi)	Defense: B/46937/Sigs 7(b)/2944	06.09.2022			

The PTCC proposal submitted vide reference (i) & (ii) has been examined. The LF induction on communication circuits of BSNL with respect to details furnished vide above references (iv) have been computed. The voltage likely to be induced on paralleling communication cables of BSNL under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors as applicable have been considered. Vide reference (v) above, South Central Railway has issued No Objection Certificate (NOC). Vide reference (vi) above, DG Signals, MoD has issued No Objection Certificate (NOC) (enclosed as Annexure-II).

EPR Zones for proposed substations are mentioned below.

Name of the	Half	Fault	Resistance	d (mts)	d (mts)	d (mts)	d (mts)
proposed SS	Diagonal	Current, I	of earthmat,	at 430 V	at 650	at 7 kV	at 10
	Distance,	(kA)	R (Ohms)		V		kV
	D/2 (mts)						
230/110 kV	140.1	20	0.09	446	248	NA	NA
Ram Samudra							

As per the details submitted by BSNL vide reference (iv) above, no telephone exchanges are falling in the EPR zone of the proposed substations.

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office.

Encl.: As above

Chief Engineer

1/27028/2023

To,

1		Divisional Engineer		BSNL, Inspection Circle,1st Floor, Raj		
		(PTCC), Southern Zone		Bhavan Exchange No. 26, Sardar Patel		
				Road, Guindy, Chennai-600032		
2		Chief	Engineer,	KPTCL, State Load Despatch Centre, #28,	Copy for information	
3.	Electricity		R.C. Cross Road, Bangalore - 560009	Copy for information		

ANNEXURE-I

CEA Case No.: KNK-1005 Name of the Power line: 220 kV DC LILO line on MC existing 220 kV RTPS – Sedam DC line to the proposed 220 Samudra SS			1 I Otal Length : 9.333 Kill		
S.No.	Telecom. Details	Length of Parallelis m in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
BSNL Letter No: SR-PTCC/SKT 4128/3 Date: 05.12.2022 I A YADGIR TELEPHONE EXCHANGE CABLES					
1	Exchange to Railway Station Road (A-A1)				
2	Exchange to Railway Station Road to Railway Station (A-A1-A2)				
3	Exchange to Railway Station Road to Chittapur Road (A-A1-A3)				
4	Exchange to Railway Station Road to Chittapur Road to Vidhansoudha Road (A-A1-A3-A8)				
5	Exchange to Gunj Circle (A-A4)				
6	Exchange to Market Road (A-A5)				
7	Exchange to Bandehalli Road (A-A6)				
8	Exchange to Mudnal Road (A-A7)				
9	Exchange to PWD Road (A-A9)				

Tele: 230197 File No.CEA-PS-17-11(14)/43/2022 PCD Division General of Signals

/27028/2023

Signals 7
General Staff Branch
Integrated HQ of MoD, (Army)
DHQ PO, New Delhi – 110011

B/46937/Sigs 7(b)/2944/

OG Sep 2022

Office of the Chief Engineer Electricity, Karnataka Power Transmission Corporation Limited State Load Despatch Centre, # 28, Race Course Cross Road, Bengaluru – 560 009

PTCC PROPOSAL FOR CONSTRUCTION OF 220KV DC LILO LINE ON MC TOWERS FROM EXISTING 220KV RTPS-SEDAM DC LINE TO THE PROPOSED 220/110KV RAM SAMUDRA SS IN YADGIRI TALUK AND DISTRICT

- 1. Refer your letter No CEE/SLDC/PTCC/F-3420/-3297-3305 dt 07 Jul 2022 (copy att).
- 2. No Objection Certificate (NOC) is accorded based on inputs provided as per Map sheets received vide your letter mentioned above.
- 3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(PS Samyal)
Col
GSO 1 (Comn)
for ADG T

Enclosures : As above

Copy to :-

The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi – 110016

- for information

The DET(PTCC), Northern Zone
O/o PGM (North), QA & Inspection Circle,
D-Tax Building, Eastern Court, Janpath
New Delhi-110001

St Proteck

