File No.CEA-PS-17-11(14)/64/2022-PCD Division









भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत संचार विकास प्रभाग Power Communication Development Division

CEA Case No. : TN-705 PTCC approval for 33 kV DC OH line for feeder no. 1 & 2 from 230/33 kV JSW Villathikulam				
S/S at Arunkulam Village to proposed JSW Wind 33 kV Wind Power Unit S/S of M/s JSW Future Energy Ltd at Arunkulam village - regd.				
S. No	Reference No.	Dated		
(i)	M/s JSWFEL: JSWFEL/33PTCC/DC-01	29.08.2022		
(ii)	BSNL: SR-PTCC/STN 1726-1728/08	11.02.2023		
(iii)	Southern Railway: W.384/3/6/6(TN) received via JSWFEL email dated 20.02.2023	23.12.2022		
(iv)	Defense: B/46937/Sigs 7(b)/3121	03.01.2023		

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on communication circuits of BSNL with respect to details furnished vide above references (ii) have been computed. The voltage likely to be induced on paralleling communication cables of BSNL under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors as applicable have been considered. Vide reference (iii) above, Southern Railway has issued No Objection Certificate (NOC). Vide reference (iv) above, DG Signals, MoD has issued No Objection Certificate (NOC) (enclosed as Annexure-II).

Name of the	Half	Fault	Resistance	d (mts)	d (mts)	d (mts)	d (mts)
proposed SS	Diagonal	Current, I	of earthmat,	at 430 V	at 650	at 7 kV	at 10
	Distance,	(kA)	R (Ohms)		V		kV
	D/2 (mts)						
230/33 kV	84.85	31.255	0.1084	583.69	357.42	NIL	NIL
JSW							
Villathikulam							
33 kV Wind	10.61	10.2	0.334	73.42	44.98	NIL	NIL
Power Unit s/s							

EPR Zones for proposed substations are mentioned below.

As per the details submitted by BSNL vide reference (ii) above, no telephone exchanges are falling in the EPR zone of the proposed substations.

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office.

Encl.: As above

Chief Engineer

NRPC Complex, Katwaria Sarai, New Delhi-110016 Telephone: 011-26565214 Email: cepcd.cea@gov.in Website: www.cea.nic.in

I/26739/2023

2	10,			
	1.	Divisional Engineer	BSNL, Inspection Circle,1st Floor, Raj	
		(PTCC), Southern Zone	Bhavan Exchange No. 26, Sardar Patel	
			Road, Guindy, Chennai-600032	
2.	M/s JSW Future Energy	JSW Centre, Bandra Kurla Complex,	Copy for information	
	Ltd	Bandra (East), Mumbai - 400051	Copy for information	

ANNEXURE-I

CEA C	Case No.: TN-705						
Name of the Power line: 33 kV DC OH line for feeder no. 1 & 2 from			Map Scale : 1 cm= 500 m				
	230/33 kV JSW Villathikulam S/S at Arunkulam Village to proposed JSW Wind 33 kV Wind Power Unit S/S of M/s JSW Future Energy Ltd at Arunkulam village			Total Length : 5.35 km S.R. Value : 15000 Ohm-cm			
		Length of		Effective			
		C	Mutual		I.V		
		Parallelis	Coupling	Fault current	in		
		m		current			
S.No.	Telecom. Details	in Km.	in Ohms.	in Amps.	Volts.		
		STN 1726-1728	3/08 Date: 11	.02.2023	1		
I VKM	VILATHIKULAM TELEPHONE EXCHANGE						
1	EXGE TO P.26 TO DP 2603						
2	EXGE TO P.26 TO DP 2609	-					
3	EXGE TO P.26 TO DP 2610						
4	EXGE TO P.26 TO DP 2611						
5	EXGE TO P.26 TO DP 2612						
6	EXGE TO P.26 TO DP 2622A	-					
7	EXGE TO P.26 TO DP 2622B	-					
8	EXGE TO P.26 TO DP 2623	-	IV less than 430 V				
9	EXGE TO P.26 TO DP 2628						
10	EXGE TO P.26 TO DP 2629						
11	EXGE TO P.26 TO DP 2631A						
12	EXGE TO P.26 TO DP 2631B						
13	EXGE TO P.26 TO DP 2632A						
14	EXGE TO P.26 TO DP 2635A						
15	EXGE TO P.26 TO DP 2635B						
16	EXGE TO P.26 TO DP 2636A						
17	EXGE TO P.26 TO DP 2637						
18	EXGE TO P.26 TO DP 2638						
EPV	EPPODUMVENDRAN TELEPHONE EXCHANGE						
1	EXGE TO DP 0001						
2	EXGE TO DP 0010	1					
3	EXGE TO DP 0011	1	IV less than 430 V				
4	EXGE TO DP 0009						
5	EXGE TO DP 0008						
6	EXGE TO DP 0016						
7	EXGE TO DP 0026						
8	EXGE TO DP 0045						
9	EXGE TO DP 0046						
10	EXGE TO DP 0047B						
11	EXGE TO DP 0048						

File No.CEA-PS-17-11(14)/64/2022-PCD Division

Tele: 23019746

2023

Annexure-II

TN-705 Directorate General of Signals Signals 7 General Staff Branch Integrated HQ of MoD, (Army) DHQ PO, New Delhi – 110011

Jan 2023

B/46937/Sigs 7(b)/3121/

.

JSW Future Energy Limited (formerly JSW Solar Limited) JSW Centre, Bandra Kurla Complex Bandra (East), Mumbai-400051

PTCC PROPOSAL FOR CONSTRUCTION OF PROPOSED 33KV D/C LINE FOR FEEDER NO.-1&2 FROM PROPOSED M/S JSW FUTURE ENERGY LTD TO PROPOSED FOUR POLE STRUCTURE FOR 300MW WIND POWER PROJECT AT ARUNKULAM VILLAGE, THOOTHUKUDI DISTRICT

1. Refer your letter No JSWFEL/33PTCC/DC-01 dt 08 Aug 2022 (copy att).

2. **No Objection Certificate (NOC) is accorded** based on inputs provided as per Map sheets received vide your letter mentioned above.

3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

SK Sharma) Lt Col GSO 1 (Comn) for Offg ADG T

Enclosures : As above

Copy to :-

The Divisional Engineer (PTCC) 'D Wing, 3rd Floor, Admn Bdg Telecom Complex, Juhu Tara Road, Santracruz West, Mumbai – 400054

The Director (PTCC), CEA Power Communication Development Division NRPC Complex, 18-A Shaheed Jeet Singh Marg Katwaria Sarai, New Delhi – 110016

The DET(PTCC), Northern Zone Bharat Sanchar Nigam Limited O/d PGM (North), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath New Delhi-110001 - for information

