





### भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत संचार विकास प्रभाग

#### **Power Communication Development Division**

\*\*\*\*\*\*

CEA Case No.: TN-706					
PTCC approval for 33 kV DC OH line for feeder no. 3 & 4 from 230/33 kV JSW Villathikulam S/S at Arunkulam Village to proposed JSW Wind 33 kV Wind Power Unit S/S of M/s JSW Future Energy Ltd at Arunkulam village - regd.					
S. No	Reference No.	Dated			
(i)	M/s JSWFEL: JSWFEL/33PTCC/DC-02	29.08.2022			
(ii)	BSNL: SR-PTCC/STN 1726-1728/08	11.02.2023			
(iii)	Southern Railway: W.384/3/6/7(TN) received via JSWFEL email dated 20.02.2023	23.12.2022			
(iv)	Defense: B/46937/Sigs 7(b)/3123	03.01.2023			

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on communication circuits of BSNL with respect to details furnished vide above references (ii) have been computed. The voltage likely to be induced on paralleling communication cables of BSNL under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors as applicable have been considered. Vide reference (iii) above, Southern Railway has issued No Objection Certificate (NOC). Vide reference (iv) above, DG Signals, MoD has issued No Objection Certificate (NOC) (enclosed as Annexure-II).

EPR Zones for proposed substations are mentioned below.

Name of the	Half	Fault	Resistance	d (mts)	d (mts)	d (mts)	d (mts)
proposed SS	Diagonal	Current, I	of earthmat,	at 430 V	at 650	at 7 kV	at 10
	Distance,	(kA)	R (Ohms)		V		kV
	D/2 (mts)						
230/33 kV	84.85	31.255	0.1084	583.69	357.42	NIL	NIL
JSW							
Villathikulam							
33 kV Wind	10.61	10.2	0.334	73.42	44.98	NIL	NIL
Power Unit s/s							

As per the details submitted by BSNL vide reference (ii) above, no telephone exchanges are falling in the EPR zone of the proposed substations.

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office.

Encl.: As above

**Chief Engineer** 

# 1/26740/2023

# To,

1.	Divisional Engineer	BSNL, Inspection Circle,1st Floor, Raj	
	(PTCC), Southern Zone	Bhavan Exchange No. 26, Sardar Patel	
		Road, Guindy, Chennai-600032	
2	M/s JSW Future Energy	JSW Centre, Bandra Kurla Complex,	Conv for information
۷.	Ltd	Bandra (East), Mumbai - 400051	Copy for information

EXGE TO P.25 TO DP 2507

EXGE TO P.26 TO DP 2603

EXGE TO P.26 TO DP 2604

EXGE TO P.26 TO DP 2605 EXGE TO P.26 TO DP 2606

EXGE TO P.26 TO DP 2609 EXGE TO P.26 TO DP 2610

EXGE TO P.26 TO DP 2611

EXGE TO P.26 TO DP 2612

24

25

2627

28 29

30 31

32

				ANNEXUR	<u>E-I</u>	
CEA C	ase No.: TN-706					
Name of the Power line: 33 kV DC OH line for feeder no. 3 & 4 fr			Map Scale	: 1 cm= 500 m	1	
230/33 kV JSW Villathikulam S/S at Arunkulam Village to pro		roposed JSW	Total Length	13.05 km		
	3 kV Wind Power Unit S/S of M/s JSW Future E	Energy Ltd at				
Arunku	lam village		S.R. Value	: 15000 Ohm-cm	1	
		Length of		Effective		
		Parallelis	Mutual	Fault	I.V	
		m	Coupling	current	in	
S.No.	Telecom. Details	in Km.	in Ohms.	in Amps.	Volts.	
BSNL Letter No: SR-PTCC/STN 1726-1728/08 Date: 11.02.2023						
I VKM	VILATHIKULAM TELEPHONE EXCHANGE					
1	EXGE TO DP 0001					
2	EXGE TO DP 002A					
3	EXGE TO DP 002B					
4	EXGE TO DP 0006					
5	EXGE TO DP 0007					
6	EXGE TO DP 0008					
7	EXGE TO DP 0014					
8	EXGE TO DP 0015					
9	EXGE TO DP 0016					
10	EXGE TO P.21 TO DP 2102					
11	EXGE TO P.21 TO DP 2104					
12	EXGE TO P.22 TO DP 2210					
13	EXGE TO P.22 TO DP 2211					
14	EXGE TO P.22 TO DP 2212		IV less t	than 430 V		
15	EXGE TO P.23 TO DP 2307					
16	EXGE TO P.23 TO DP 2308					
17	EXGE TO P.23 TO DP 2309					
18	EXGE TO P.23 TO DP 2310					
19	EXGE TO P.23 TO DP 2311					
20	EXGE TO P.23 TO DP 2312					
21	EXGE TO P.24 TO DP 2401					
22	EXGE TO P.24 TO DP 2404					
23	EXGE TO P.25 TO DP 2501					

#### 1/26740/2023

33	EXGE TO P.26 TO DP 2622A				
34	EXGE TO P.26 TO DP 2622B				
35	EXGE TO P.26 TO DP 2623		IV less than 430 V		
36	EXGE TO P.26 TO DP 2628				
37	EXGE TO P.26 TO DP 2629				
38	EXGE TO P.26 TO DP 2631A				
39	EXGE TO P.26 TO DP 2631B				
40	EXGE TO P.26 TO DP 2632A				
41	EXGE TO P.26 TO DP 2635A				
42	EXGE TO P.26 TO DP 2635B				
43	EXGE TO P.26 TO DP 2636A				
44	EXGE TO P.26 TO DP 2637				
45	EXGE TO P.26 TO DP 2638				
EPV	EPPODUMVENDRAN TELEPHONE				
	EXCHANGE				
1	EXGE TO DP 0010	_			
2	EXGE TO DP 0011	_			
3	EXGE TO DP 0008		IV less than 430 V		
4	EXGE TO DP 0046				
5	EXGE TO DP 0047B				
6	EXGE TO DP 0048				
7	EXGE TO DP 0045		T	T	1
KUL	KULATHUR TELEPHONE EXCHANGE				
1	EXGE TO DP 0002				
2	EXGE TO DP 0003				
3	EXGE TO DP 0005				
4	EXGE TO DP 0008				
5	EXGE TO DP 0010				
6	EXGE TO DP 0011		IV loss s	than 430 V	
7	EXGE TO DP 0016		1 v 1688 (	11a11 430 V	
8	EXGE TO DP 0022				
9	EXGE TO DP 0030				
10	EXGE P.23 TO DP 2307A				
11	EXGE P.23 TO DP 2309A				
12	EXGE P.24 TO DP 2410				
13	EXGE P.24 TO DP 2411				
14	EXGE P.24 TO DP 2412	]			

File No.CEA-PS-17-11(14)/18/2023-PCD Division

26742/2023

Tele: 23019746

Directorate General of Signals
Signals 7 Annexure-II
General Staff Branch
Integrated HQ of MoD, (Army)
DHQ PO, New Delhi – 110011

B/46937/Sigs 7(b)/3123/

JSW Future Energy Limited (formerly JSW Solar Limited) JSW Centre, Bandra Kurla Complex Bandra (East), Mumbai-400051 0≯ Jan 2023

# PTCC PROPOSAL FOR CONSTRUCTION OF PROPOSED 33KV D/C LINE FOR FEEDER NO.-3&4 FROM PROPOSED M/S JSW FUTURE ENERGY LTD TO PROPOSED FOUR POLE STRUCTURE FOR 300MW WIND POWER PROJECT AT ARUNKULAM VILLAGE, THOOTHUKUDI DISTRICT

- 1. Refer your letter No JSWFEL/33PTCC/DC-02 dt 08 Aug 2022 (copy att).
- 2. **No Objection Certificate (NOC) is accorded** based on inputs provided as per Map sheets received vide your letter mentioned above.
- 3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

<del>\_(SK Sharma)</del>

Lt Col

GSO 1 (Comn)

for Offg ADG T

Enclosures : As above

Copy to :-

The Divisional Engineer (PTCC)

'D' Wing, 3<sup>rd</sup> Floor, Admn Bdg
Telecom Complex,
Juha Tara Road,
Santracruz West, Mumbai – 400054

The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi – 110016

The DET(PTCC), Northern Zone
Bharat Sanchar Nigam Limited
O/o PGM (North), QA & Inspection Circle,
D-Tax Building, Eastern Court, Janpath
New Delhi-110001

- for information

