

I/26927/2023



सत्यमेव जयते

भारत गुरुकुल
ONE EARTH • ONE FAMILY • ONE FUTURE

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

CEA Case No. : UP-598		
PTCC approval for Extension of 220 kV bus bar of Sahupuri (220) to 220 kV bus bar of 400/220 kV GIS Sahupuri S/S and Diversion of 220 kV DC Sahupuri-Bhelpur Transmission line with underground XLPE Copper cable. -Regd.		
S. No	Reference No.	Dated
(i)	UPPTCL: 1081/ETD (S) /	22.06.2022
(ii)	UPPTCL: वि०प्रे०ख०-तृ० (सा०)	29.09.2022
(iii)	UPPTCL: 132/वि०प्रे०ख०-तृ० (सा०)	08.02.2023
(iv)	BSNL: DET/PTCC/ND/DV-10133/UP-1091/2022-23	20.09.2022
(v)	Northern Railway: 342-SIG/1/PTCC/2022-23/07/06	14.07.2022
(vi)	North Central Railway: एनसीआर/एसएंडटी/2074/टेलीकॉम/पीटीसीसी (पार्ट-1)	01.09.2022
(vii)	Defense: B/46937/Sigs7(b)/2930	26.09.2022

The PTCC proposal submitted vide reference (i), (ii) and (iii) has been examined. Vide above reference (iii), UPPTCL has mentioned that new 400/220 kV GIS S/S is being constructed within the premises of old 220/132/33 kV S/S.

All the proposed work i.e extension of 220 kV Bus Bar of existing 220/132/33 kV S/S to 220 kV Bus Bar of 400/220 kV GIS S/S and diversion of 220 kV Sahupuri-Bhelpur transmission to 220 kV Bus Bar of 400 kV GIS S/S is being done within the premises of original 220/132/33 kV S/S. Accordingly, fresh PTCC approval is not required in this particular case.

Chief Engineer

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL, O/o PGM(North), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath New Delhi-110001	
2.	GM (S&T)	Northern Railway, Baroda House New Delhi	
3.	GM (S&T)	North Central Railway, HQ Office Ganga Parisar, Subedarganj Allahabad	
4.	Executive Engineer, UPPTCL	Electricity Transmission Division-III UPPTCL Sahupuri-Varanasi	Copy for information.