

I/28253/2023



सत्यमेव जयते

भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

विद्युत संचार विकास प्रभाग

Power Communication Development Division

\*\*\*\*\*



CEA Case No. : AND-702		
PTCC approval for diversion of existing 220 kV Renigunta – G. D. Nellore DC line by laying 2 km of 220 kV DC UG cable and erection of 2 nos. D type towers and 2 nos. CTT towers - regd.		
S. No	Reference No.	Dated
(i)	APTRANSCO: CE-Proj/SE-220&132kV/EE-1/DEE-1/F.Airport/ PTCC/D.No.30/23	27.01.2023
(ii)	APTRANSCO: CE-Proj/SE-220&132kV/EE-1/DEE-1/F.Airport/ PTCC/D.No.122/23	19.04.2023
(iii)	BSNL: SR-PTCC/SAP2934/06	24.02.2021
(iv)	Southern Railway: W.384/3/5/97A	29.09.2020
(v)	South Central Railway: SG.85/4/3/PTCC/SCR/2022-23/AP-20RTD	29.03.2023
(vi)	Defense: B/46937/Sigs 7(b)/3208	31.05.2023

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on communication circuits of BSNL, Southern Railway and South Central Railway with respect to details furnished vide above references (iii), (iv) and (v) respectively have been computed. The voltages likely to be induced on paralleling communication cables of BSNL, Southern Railway and South Central Railway under Single Line to Ground fault condition are enclosed at Annexure-I, II and III respectively. The screening factors as applicable have been considered. Vide reference (vi) above, DG Signals, MoD has issued No Objection Certificate (NOC) (enclosed as Annexure-IV).

The instant PTCC case is related to diversion of existing line, therefore, EPR zone verification is not required.

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office.

Encl.: As above

Chief Engineer

To,

1.	Divisional Engineer (PTCC), Southern Zone	BSNL, Inspection Circle, 1st Floor, Raj Bhavan Exchange No. 26, Sardar Patel Road, Guindy, Chennai-600032	
2.	GM (S&T)	Southern Railway, Head Quarters Office, S&T Branch, Chennai – 600003	
3.	GM (Tele)	South Central Railway, O/o PCSTE, 7 <sup>th</sup> Floor, Rail Nilayam, Secunderabad - 500025	
4.	Chief Engineer, Projects	APTRANSCO, Vidyut Soudha, Vijayawada - 520004	Copy for information

I/28253/2023

ANNEXURE-I

CEA Case No.: AND-702		Map Scale : 1 cm= 500 m							
Name of the Power line: Diversion of existing 220 kV Renigunta – G. D. Nellore DC line by laying 2 km of 220 kV DC UG cable and erection of 2 nos. D type towers and 2 nos. CTT towers		Total Length : 1.698 km UG & 0.298 km OH							
		S.R. Value : 10,000 Ohm-cm							
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.				
<b>BSNL Letter No: SR-PTCC/SAP2934/06 Date: 24.02.2021</b>									
<b>I G</b>	<b>GAJULAMANDYAM EXCHANGE UG CABLE</b>								
1	Exge to Pillar 62 to DP 11 (G-G1)	IV less than 430 V							
<b>II A</b>	<b>AIRPORT EXCHANGE UG CABLE</b>								
1	Exge to Airport DP (A-A1)	IV less than 430 V							
2	Exge to Pillar 14 to DP 10 (A-A2)								
3	Exge to Pillar 14 to DP 2 (A-A3)								
4	Exge to DP 22 (A-A4)								
<b>III R</b>	<b>RENIGUNTA EXCHANGE UG CABLE</b>								
1	Exge to Pillar 27 (R-R1)	IV less than 430 V							
2	Exge to Pillar 51 (R-R2)	0.8	0.0284	10812	307				
3	Exge to Pillar 31 to DP 19 (R-R3)	IV less than 430 V							
4	Exge to Pillar 32 to DP 13 (R-R4)								
5	Exge to Pillar 34 to DP 20 (R-R5)								
6	Exge to Pillar 33 to DP 16 (R-R6)								
7	Exge to Pillar 22 (R-R7)								
8	Exge to Pillar 34 to DP 25 (R-R8)	IV less than 430 V							
<b>IV K</b>	<b>KARAKAMBADI EXCHANGE UG CABLE</b>								
1	Exge to Mini Pillar to DP 18 (K-K1)					IV less than 430 V			

I/28253/2023

2	Exge to Pillar 31 to Amararaja (K-K2)	IV less than 430 V
3	Exge to Pillar 31 to Grindwelnorton (K-K3)	

I/28253/2023

ANNEXURE-II

<b>CEA Case No.:</b> AND-702  <b>Name of the Power line:</b> Diversion of existing 220 kV Renigunta – G. D. Nellore DC line by laying 2 km of 220 kV DC UG cable and erection of 2 nos. D type towers and 2 nos. CTT towers			<b>Map Scale</b> : 1 cm= 500 m  <b>Total Length</b> : 1.698 km UG & 0.298 km OH  <b>S.R. Value</b> : 10,000 Ohm-cm		
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
<b>Southern Railway Letter No: W.384/3/5/97A Date: 29.09.2020</b>					
1	Pudi - Renigunta	1.7	0.0043	10290	44

I/28253/2023

**ANNEXURE-III**

<b>CEA Case No.:</b> AND-702 <b>Name of the Power line:</b> Diversion of existing 220 kV Renigunta – G. D. Nellore DC line by laying 2 km of 220 kV DC UG cable and erection of 2 nos. D type towers and 2 nos. CTT towers		<b>Map Scale</b> : 1 cm= 500 m <b>Total Length</b> : 1.698 km UG & 0.298 km OH <b>S.R. Value</b> : 10,000 Ohm-cm			
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
<b>South Central Railway Letter No: SG.85/4/3/PTCC/SCR/2022-23/AP-20RTD Date: 29.03.2023</b>					
1	Mamanduru (MRM) – Renigunta (RU)	Out of parallelism			0
2	Renigunta (RU) – Yerpedu (YPD)	0.1	0.0001	11070	1
3	Renigunta (RU) – Tiruchanuru (TCNR)	1.4	0.0023	10950	25
4	Tiruchanuru (TCNR) – Tirupati (TPTY)	0.5	0.0005	10840	5

I/28253/2023

Tele : 23019746

Directorate General of Signals  
Signals 7  
General Staff Branch  
Integrated HQ of MoD, (Army)  
DHQ PO, New Delhi – 110011

B/46937/Sigs 7(b)/3208

31 May 2023

Chief Engineer, Projects  
APTRANSCO  
Transmission Corporation of Andhra Pradesh Limited  
Vidyut Soudha, Vijayawada– 520004

**SUPPLY, ERECTION, TESTING AND COMMISSIONING OF (I) DIVERSION OF 220KV RENIGUNTA-G.D. NELLORE DC LINE BY LAYING 2KM OF 220KV DC UG CABLE AND ERECTION OF 2NOS D TYPE TOWERS AND 2NOS CTT TOWERS (II) DIVERSION OF 132KV RENIGUNTA-CHITTOOR SC LINE BY LAYING 2KM OF 132KV SC UG CABLE AND ERECTION OF 3NOS S TYPE TOWERS AND 2NOS CTT TOWERS AND (III) DIVERSION OF 132KV RENIGUNTA-PUTTUR DC LINE BY LAYING 2KM OF 132KV DC UG CABLE AND ERECTION OF 3NOS NB+60 TOWERS AND 2NOS CTT TOWERS IN CHITTOOR DISTRICT-PTCC PROPOSAL**

1. Refer your letter No Lr. No. CE-Proj./SE-220&132KV/EE-1/DEE-1/F.Airport/PTCC/D.No. 30/23 dt 27 Jan 2023 (copy att).
2. **No Objection Certificate (NOC) is accorded** based on inputs provided as per Map sheets received vide your letter mentioned above.
3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.



(SK Sharma)  
Lt Col  
GSO 1 (Comn)  
for ADG T

**Enclosures** : As above

**Copy to :-**

The Director (PTCC), CEA  
Power Communication Development Division  
NRPC Complex, 18-A Shaheed Jeet Singh Marg  
Katwaria Sarai, New Delhi – 110016

- for information

The DET(PTCC), Northern Zone  
Bharat Sanchar Nigam Limited  
O/o PGM (North), QA & Inspection Circle,  
D-Tax Building, Eastern Court, Janpath  
New Delhi-110001