

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

Subject: - PTCC clearance for modification/diversion work of 220 kV D/C Misa Kopili Transmission Line to maintain vertical electrical clearance of Railway Crossing Towers.

POWERGRID vide Letter no. NEMS/PTCC_Clearance/2023-24/85 dated 24.06.2023 has requested to review requirement of PTCC NOC/clearance in respect of diversion/modification of existing 220 kV D/C Misa Kopili Transmission Line to extent of lateral diversion of 95 m to maintain vertical electrical clearance of Railway Crossing Towers.

The received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/diversion of the existing 220 kV D/C Misa Kopili Transmission Line from tower no: 172 to 174.



(Suman Kumar Maharana)
Chief Engineer

To,
DGM, POWERGRID
Misa Sub Station, Dist. Hojal
Assam

Copy to: -

PPS to Member (PS), Central Electricity Authority, Sewa Bhawan, RK Puram-110016