





भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विदयुत संचार विकास प्रभाग

Power Communication Development Division

CEA Case No.: MRA-1216

Induced Voltage (IV) calculation for PTCC proposal of 220 kV D/C line from Jejuri (400 kV) S/s to Lonand (220 kV) S/s by laying new section from Jejuri (400 kV) S/s to location No. 28 of existing 220 kV line from Jejuri (220 kV) S/s to Lonand (220 kV) S/s (7.24 km) - regd.

S. No	Reference No.	Dated
(i)	MSETCL: MSETCL/CO/PS/PTCC/In/B-594/00924	08.02.2023
(ii)	MSETCL: Email	05.09.2023
(iii)	BSNL: IC/MBI/PTCC/MRA-2581/03	02.05.2023
(iv)	Central Railway: N.153/PTCC/220kV/MAH-829	27.02.2023
(v)	Defense: B/46937/Sigs 7(b)/3240	31.07.2023

The PTCC proposal submitted vide reference (i) & (ii) has been examined. The LF induction on communication circuits of BSNL and Central Railway with respect to details furnished vide above references (iii) & (iv) respectively have been computed. The voltages likely to be induced on paralleling communication circuits of BSNL and Central Railway under Single Line to Ground fault condition are enclosed at Annexure-I & II respectively. The screening factors as applicable have been considered. Defense has issued No Objection Certificate (NOC) vide above reference (v) (copy enclosed as Annexure-III). EPR details verification is not required as substations are existing.

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office.

Encl.: As above

(लाज जे वि) Director

To,

10,					
1.	Divisional	QA & Inspection circle, 1st floor, D- wing,			
	Engineer (PTCC),	BSNL Admin Bldg., Junu Tara Road, Santacruz			
	Western Zone				
2.	2. General Manager Central Railway, O/o PCSTE, S&T Dept., 3 rd				
	(S&T)	floor, Annexe Building, Chhatrapati Shivaji			
		Maharaj Terminus, Mumbai - 400001			
3.	Superintending Engineer (Project Schemes)	MSETCL, O/o Superintending Engineer (Project Schemes Dept.), Prakashganga, P. No. C19, #E, BKC, Bandra (East), Mumbai - 400051	Copy for information		

ANNEXURE-I

Name o	ase No.: MRA-1216 of the Power line: 220 kV D/C line from 400 kV Jejust fexisting 220 kV Jejuri – Lonand line (to provide discussion and 220 kV Baramati S/s from 400 kV Jejust – Lonand S/s and 220 kV Baramati S/s from 400 kV Baramati S/s from 4	rect source to	Total Length	: 1 cm= 500 n : 7.24 km : 10000 Ohm-cn	
S.No.	Telecom. Details	Length of Parallelis m in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
	BSNL Letter No: IC/MBI/PTCC/	MRA-2581/03	B Date: 02.05.	2023	
1	Jejuri 400 Pr X 2 Nos	-	IV less t	han 430 V	
2	Walha 200 Pr X 1 Nos		17 1035 t	пан 130 у	

ANNEXURE-II

Map Scale : 1 cm= 500 m

CEA Case No.: MRA-1216

Total Length: 7.24 km

Name of the Power line: 220 kV D/C line from 400 kV Jejuri S/s to loc. no. 28 of existing 220 kV Jejuri - Lonand line (to provide direct source to

S.R. Value: 10000 Ohm-cm

220 kV Lonand S/s and 220 kV Baramati S/s from 400 kV Jejuri S/s)

S.No.	Telecom. Details	Length of Parallelis m in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
	Central Railway Letter No: N.153/PTC	CC/220kV/MAI	H-829 Date: 2	27.02.2023	
1	Rajewadi - Jejuri	0.4	0.0001	26627	3
2	Jejuri - Daundaj	6.8	0.0012	19167	23
3	Daundaj - Walha			0	
4	Walha – Nira	Out of parallelism			0

File No.CEA-PS-17-11(12)/41/2023-PCD Division

I/30827/2023 = : 23019746

Directorate General of Signals
Signals 7 MRA - 12 | 6

General Staff Branch Integrated HQ of MoD (Army) DHQ PO, New Delhi - 110011

B/46937/Sigs 7(b)/3240/

3\ Jul 2023

Office of the Superintending Engineer,
Projects Schemes Department
Maharashtra State Electricity Transmission Co Ltd
"Prakashganga", Plot No C-19, 'E' Block,
Bandra – Kurla Complex, Bandra (East),
Mumbai-400051

PTCC PROPOSAL FOR 220KV DC LINE FROM 400KV JEJURI S/S TO LOC. NO .
28 OF EXISTING 220KV JEJURI-LONAND LINE (TO PROVIDE DIRECT SOURCE TO 220KV LONAND S/S AND 220KV BARAMATI S/S FROM 400KV JEJURI S/S),
LENGTH=7.24KMS

- 1. Refer your letter No MSETCL/CO/PS/PTCC/In/B-594/No 00924 dt 08 Feb 2023 (copy att).
- 2. **No Objection Certificate (NOC) is accorded** based on inputs provided as per Map sheets received vide your letter mentioned above.
- 3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(SP Choyal)

Lieutenant Colonel

General Staff Officer Grade 1 (Communication) for Additional Director General (Telecommunication)

Enclosures: As above

Copy to :-

The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeet Singh Marg

Katwaria Sarai, New Delhi - 110016

for information

The DET(PTCC), Northern Zone Bharat Sanchar Nigam Limited O/o PGM (North), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath

New Delhi-110001

Central Electricity Authority
PCD Division
iary No 71

DX (PCD) Sh Atuhay, DD Xn

74. 37414 1618