





भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत संचार विकास प्रभाग

Power Communication Development Division

CEA Case No.: MRA-1218 Induced Voltage (IV) calculation of PTCC proposal for LILO of 220 kV Kalwa- Apta line with UG cable at 220 kV GIS S/s of M/s Print House (India) Pvt. Ltd. (0.3 Kms) – Regd.				
S. No	Reference No.	Dated		
(i)	PH/PR/ADMIN/MUM-RABALE/42/2023	12.05.2023		
(ii)	BSNL: IC/MBI/PTCC/MRA-2589/03	10.08.2023		
(iii)	Central Railway: N.153/PTCC/220kV/MAH-835	16.06.2023		
(iv)	Defense: B/46937/Sigs 7(b)/3380	13.09.2023		

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on communication circuits of MTNL and Central Railway with respect to details furnished vide above reference (ii) and (iii) respectively have been computed. The voltage likely to be induced on paralleling communication circuits of MTNL and Central Railway under Single Line to Ground fault condition are enclosed at Annexure-I and Annexure-II respectively. The screening factors as applicable have been considered.

DG Signals, MoD, vide above reference (iv) has issued their No Objection certificate (NOC) for charging of the line.

EPR zone for the proposed substation is mentioned below:

		1 The state of the					
Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/11 kV GIS	30	35	. 0.24	556	358	6	NA
Substation of							
Print House							
India (Pvt.)							
Ltd.							

As per the details submitted by BSNL vide reference (ii) above, no telephone exchanges are falling in the EPR zone of the proposed substation.

Taking above into consideration, necessary action regarding issuance of PTCC approval for the subject cited transmission line may be taken under intimation to this office.

Encl.: As above

(Md. 13.10.2023 (Md. 13.10.2023 Director

1/30953/2023

To,

1.	Divisional	QA & Inspection circle,		
	Engineer (PTCC),	1st floor, D- wing, BSNL Admin Bldg.,		
	Western Zone	Junu Tara Road, Santacruz (West),		
		Mumbai-400054		
2.	GM (S&T)	Central Railway, Office of Principal Chief Signal and		
		Telecom Engineer, 3 rd Floor, Annex Building, CSMT		
		Mumbai, 400 001		
2.	M/s Print House	Plot No. R-847/2, T.T.C Industrial, Rabale, Rabale,	Copy f	for
۷.	(India) Pvt. Ltd.	Navi Mumbai	information	

ANNEXURE-I Map Scale : 1 cm = 500 mTotal Length: 0.3 km CEA Case No.: MRA-1218 S.R. Value: 5000 Ohm-cm Name of the Power line: LILO of 220 kV Kalwa- Apta line with UG cable at 220 kV GIS S/s of M/s Print House (India) Pvt. Ltd. Length of Effective Mutual I.V **Parallelis** Fault m Coupling current in S.No. Telecom. Details in Km. in Ohms. in Amps. Volts. BSNL: IC/MBI/PTCC/MRA-2589/03 Dated: 10.08.2023 1 EL Zone RSU Out of parallelism 2 KKR Out of parallelism 3 MBP Out of parallelism 4 Rabale IV Less than 430 V 5 Airoli Out of parallelism 6 Vashi Out of parallelism APMC 7 Out of parallelism Turbhe 8 Out of parallelism 9 Kausa Out of parallelism 10 NMUM Out of parallelism 11 Riverwood Out of parallelism 12 Diva Rly Stn Out of parallelism 13 Kalwa Out of parallelism 14 Kopri Out of parallelism 15 **PPK** Out of parallelism 16 CHR Out of parallelism Mulund 17 Out of parallelism 18 Bhandup BTM Out of parallelism

1/30953/2023

19	Manisha Tower	Out of parallelism

ANNEXURE-II

CEA Case No.: MRA-1218 Name of the Power line: LILO of 220 kV Kalwa- Apt cable at 220 kV GIS S/s of M/s Print House (India) Pvt. L			Map Scale : 1 cm= 500 m Total Length : 0.3 km S.R. Value : 5000 Ohm-cm Effective		,	
S.No.	Telecom. Details	Parallelis m in Km.	Mutual Coupling in Ohms.	Fault current in Amps.	I.V in Volts.	
	Central Railway: N.153/PTCC/2	220kV/MAH-83				
1	Bhandup to Dombivli		Out of parallelism			
2	Thane to Jui Nagar		Out of parallelism			
3	Diva to Taloja		Out of parallelism			