

I/30908/2023



सत्यमेव जयते



ONE EARTH - ONE FAMILY - ONE FUTURE

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

CEA Case No. : HP-71		
Induced Voltage (IV) computation for PTCC proposal of 220 kV Transmission Line on M/C Tower from 400/220 kV PGCIL PSS Kala-Amb to 220/132/33 kV AIS of HPPTCL at Andheri. [Length- 3.6 km] – Regd.		
Reference :		
S. No.	Reference No .	Dated
(i)	HPPTCL Letter No : HPPTCL/DGM/PTCC-Approval/2023-305-312	20.04.2023
(ii)	HPPTCL e-mail	09.10.2023
(iii)	BSNL : DET/PTCC/ND/DV-10215/HP-258/2023-2024/	17.07.2023
(iv)	Northern Railway : 342-SIG/1/PTCC/N/2023/05/01	08.05.2023
(v)	Defense : B/46937/Sigs 7 (b) /3348	05.09.2023

The PTCC proposal submitted vide reference (i) & (ii) has been examined. Vide above reference (iii), (iv) & (v) DET, PTCC NZ, BSNL, AESTE, Northern Railways and DG Signals, MoD has intimated that no telecom assets exists within the vicinity of 8 km on either side of the proposed power line and have issued No Objection Certificate (NOC).

Taking above into consideration, necessary action regarding issuance of PTCC approval for the subject cited transmission line may be taken under intimation to this office .

Encl. : As above .

Director

To,

1.	Divisional Engineer (PTCC) , Northern Zone	O/o PGM(N), QA & Inspection Circle D-Tax Building, Eastern Court Janpath, New Delhi-110001	
2.	DGM & Head Trans Designs	HPPTCL Anu, Hamirpur, H.P	Copy for information