


I/28594/2023



सत्यमेव जयते



**भारत सरकार**  
**Government of India**  
**विद्युत मंत्रालय**  
**Ministry of Power**  
**केन्द्रीय विद्युत प्राधिकरण**  
**Central Electricity Authority**  
**विद्युत संचार विकास प्रभाग**  
**Power Communication Development Division**  
 \*\*\*\*\*

CEA Case No. : RAJ-707		
Induced Voltage (IV) calculation for PTCC proposal of LILO of 220 kV S/C Balotra – HRRL line at 400 kV Pachpadra S/s [Length-5.076 km] - Regd.		
S. No	Reference No.	Dated
(i)	RVPN/SE(QC-INSP&Montg.)/XEN (PTCC)/JPR/F.1954-A/D.573	27.10.2022
(ii)	RVPN/SE(QC-INSP&Montg.)/XEN (PTCC)/JPR/F.1953-A/Rajkaj No. 4000687	07.06.2023
(iii)	BSNL: DET/PTCC/ND/DV-10146/Raj-1391/2023-2024	23.05.2023
(iv)	North Western Railway: SG/158/NWR/PTCC/899	07.11.2022
(v)	Defense: B/46937/Sigs7(b)/3096	02.02.2023

The PTCC proposal submitted vide reference (i) and (ii) has been examined. DET (NZ), BSNL vide reference (iii), North Western Railway vide reference (iv) and DG Signals, MoD vide reference (v) have issued No Objection Certificate (NOC) for charging of the line.

EPR Zones for proposed substations are mentioned below:

Name of the proposed SS	Half Diagonal Distance, D/2 (mts)	Fault Current, I (kA)	Resistance of earthmat, R (Ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7 kV	d (mts) at 10 kV
400 kV Pachpadra GSS	242	35	0.10	1728	1061	NA	NA
220 kV HRRL Substation	125	28	0.12	852	521	NA	NA

Taking above into consideration, necessary action regarding issuance of PTCC approval for the subject cited transmission line might be taken under intimation to this office.

Encl.: As above

*S.K. Maharana*  
27/6/23  
**(S. K. Maharana)**  
Chief Engineer

**To,**

1.	Divisional Engineer (PTCC), Northern Zone	BSNL, O/o GM (North), QA & Inspection Circle D-Tax Building, Eastern Court, Janpath, New Delhi
2.	Superintending Engineer (QC, Inspection & Monitoring),	RVPNL Room No. 320, Vidyut Bhawan, Jyoti Nagar, Jaipur

एनआरपीसी परिसर, कटवारिया सराय, नई दिल्ली-110016 टेलीफोन-011-26565214 ईमेल- cepcd.cea@gov.in वेबसाइट- www.cea.nic.in

NRPC Complex, Katwaria Sarai, New Delhi-110016 Telephone. 011-26565214 Email: cepcd.cea@gov.in Website: www.cea.nic.in