





भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत संचार विकास प्रभाग

Power Communication Development Division

CEA Case No.: RAJ-710							
Induced Voltage (IV) calculation for PTCC proposal of LILO of one circuit of 400 kV D/C Rajwest-Kankani Transmission Line at 400 kV Pachpadra S/s [Length-36.011 km] - Regd.							
S. No	Reference No.	Dated					
(i)	RVPN/SE(QC-INSP&Montg.)/XEN (PTCC)/JPR/F.1950-A/D.575	27.10.2022					
(ii)	RVPN/SE(QC-INSP&Montg.)/XEN/F/Rajkaj No.3332335	08.03.2023					
(iii)	BSNL: DET/PTCC/ND/DV-10188/Raj-1409/2023-2024	16.08.2023					
(iv)	North Western Railway: SG/158/NWR/PTCC/901	07.11.2022					
(v)	Defense: B/46937/Sigs7(b)/3098	02.02.2023					

The PTCC proposal submitted vide reference (i) and (ii) has been examined. DET (NZ), BSNL vide reference (iii), North Western Railway vide reference (iv) and DG Signals, MoD vide reference (v) have issued No Objection Certificate (NOC) for charging of the line.

EPR Zones for proposed substation is mentioned below:

El it Zones for proposed substation is mentioned selow.								
Name of	the	Half	Fault	Resistance	d (mts)	d (mts)	d (mts)	d (mts)
proposed SS		Diagonal	Current, I	of earthmat,	at 430 V	at 650	at 7 kV	at 10
		Distance,	(kA)	R (Ohms)		V		kV
		D/2 (mts)	, ,					
400	kV	242	35	0.10	1728	1061	NA	NA
Pachpadra								
GSS								

Taking above into consideration, necessary action regarding issuance of PTCC approval for the subject cited transmission line might be taken under intimation to this office.

Encl.: As above

Director

To.

10,			
1.	Divisional Engineer (PTCC),	BSNL, O/o GM (North), QA & Inspection Circle	
	Northern Zone	D-Tax Building, Eastern Court, Janpath, New	
		Delhi	
2.	Superintending Engineer (QC, Inspection & Monitoring),	RVPNL Room No. 320, Vidyut Bhawan, Jyoti Nagar, Jaipur	