





भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत संचार विकास प्रभाग Power Communication Development Division

CEA Case No.: TN-727					
Induced Voltage (IV) Calculation for PTCC proposal of 33 kV S/C OH line for Feeder No. 3 on RSJ Pole with AL59 Panther conductor and AAAC Dog conductor from 220/33 kV JSW Tuticorin – B S/s at Savlaperi village to proposed 33 kV JSW Wind Power unit substation tapping point TUT-181 (Length: 14.71 km)					
S. No	Reference No.	Dated			
(i)	JSWREL/33kV-PTCC/330 MW/SC03	15.04.2023			
(ii)	BSNL: SR-PTCC/STN 5062/05	25.08.2023			
(iii)	Southern Railway: W.384/3/6/18(TN)	12.07.2023			
(iv)	Defense: B/46937/Sigs 7(b)/3322	04.07.2023			

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on communication circuits of BSNL with respect to details furnished vide above reference (ii) has been computed. The voltage likely to be induced on paralleling communication circuits of BSNL under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors as applicable have been considered.

Southern Railway vide reference (iii) and DG Signals, MoD, vide reference (iv) (Annexure-I) have issued their No Objection certificate (NOC) for charging of the line.

EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Curre nt I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
230/33 kV JSW Tuticorin B Wind Power PSS-B of M/s JSW Renew Energy Ltd at Savlaperi village	82.54	35	0.0344	149	70	NA	NA
33 kV Wind Power unit substation	14	13.374	0.491	200	127	NA	NA

1/32281/2023

As per the details submitted by BSNL vide reference (ii) above, no telephone exchanges are falling in the EPR zone of the proposed substation.

Taking above into consideration, necessary action regarding issuance of PTCC approval for the subject cited transmission line may be taken under intimation to this office.

Encl.: As above

For Director

To,

1.	Divisional	ivisional BSNL, Inspection Circle,1st Floor, Raj Bhavan	
	Engineer (PTCC),	Exchange No. 26, Sardar Patel Road, Guindy,	
	Southern Zone	Chennai-600032	
2	M/s JSW Renew	JSW Centre, Bandra Kurla Complex, Bandra	For information
۷.	Energy Limited	(East), Mumbai – 400 051	

ANNEXURE-I

CEA Case No.: TN-727			Map Scale : 1 cm= 500 m			
Name of the Power line: 33 kV S/C OH line for Feeder No. 3 Pole with AL59 Panther conductor and AAAC Dog conduct 220/33 kV JSW Tuticorin – B S/s at Savlaperi village to propose JSW Wind Power unit substation tapping point TUT-181		nductor from	on RSJ or from SR Value : 20000 Ohm-cm			
S.No.	Telecom. Details	Length of Parallelis m in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.	
	BSNL: SR-PTCC/STN 5	6062/05 Dated:	28.08.2023			
KALUG	UMALAI TELEPHONE EXCHANGE					
1	EXGE to P.22 to DP.2208	Out of parallelism				
2	EXGE to P.22 to DP.2211					
NALAT'	TINPUTHUR TELEPHONE EXCHANGE					
1	EXGE to P.24 to DP.2406					
2	EXGE to P.24 to DP.2407		Out of parallelism			
3	EXGE to P.24 to DP.2414					
4	EXGE to P.24 to DP.2415					
5	EXGE to P.24 to DP.2419					
6	EXGE to P.24 to DP.2420					
7	EXGE to P.24 to DP.2422					
8	EXGE to P.24 to DP.2424					
9	EXGE to P.24 to DP.2427					
10	EXGE to P.24 to DP.2428					

1/32281/2023

Tele: 23019 File No.CEA-PS-17-11(14)/44/2023-PGD Division General of Signals

Signals 7
General Staff Branch
Integrated HQ of MoD, (Army)
DHQ PO, New Delhi – 110011

B/46937/Sigs 7(b)/3322/

9[∨] Jul 2023

JSW Renew Energy Limited Regd. Office: JSW Centre, Bandra Kurla Complex Bandra (East), Mumbai-400051

PTCC PROPOSAL FOR CONSTRUCTION OF PROPOSED 33KV DOUBLE CIRCUIT LINE FOR FEEDER NO-SC-03 FROM PROPOSED M/S JSW RENEW ENERGY LTD FOR TOTAL CONNECTIVITY 540MW AT PART OF PROJECT 330MW TUTICORIN-I 230/33KV POOLING SUBSTATIONS WIND POWER PROJECT AT THOOTHUKUDI DISTRICT

- 1. Refer your letter No JSWREL/33kv-PTCC/330MW/SC-03 dt 15 Apr 2023 (copy att).
- 2. **No Objection Certificate (NOC) is accorded** based on inputs provided as per Map sheets received vide your letter mentioned above.
- 3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(SP Choyal)

Lt Col

GSO 1 (Coord) for ADG T

Enclosures: As above

Copy to :-

The Divisional Engineer (PTCC)
'D' Wing, 3rd Floor, Admn Bdg
Telecom Complex,
Juhu Tara Road,
Santracruz West, Mumbai – 400054

- for information

The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi – 110016

The DET(PTCC), Northern Zone
Bharat Sanchar Nigam Limited
Olo PGM (North), QA & Inspection Circle,
D Tax Building, Eastern Court, Janpath
New Delhi-110001

Central Electricity Authority
PCD Division
liary No 6.2. Z O O B

8h. Akshay, DD Oliv 27/7 PPU. 3164 31107 Sh. Gratel