





भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत संचार विकास प्रभाग Power Communication Development Division

| CEA Case No.: TN-728 Induced Voltage (IV) Calculation for PTCC proposal of 33 kV S/C OH line for Feeder No. 4 on RSJ Pole with AL59 Panther conductor and AAAC Dog conductor from 220/33 kV JSW Tuticorin – B S/s at Savlaperi village to proposed 33 kV JSW Wind Power unit substation tapping point TUT-155 (Length: 15.0 km) | | | | |
|--|---|------------|--|--|
| S. No | Reference No. | Dated | | |
| (i) | JSWREL/33kV-PTCC/330 MW/SC04 | 15.04.2023 | | |
| (ii) | BSNL: SR-PTCC/STN 5063/05 | 25.08.2023 | | |
| (iii) | Southern Railway: W.384/3/6/19(TN) (received via JSW E-mail dated 20.11.2023) | 13.07.2023 | | |
| (iv) | Defense: B/46937/Sigs 7(b)/3321 | 04.07.2023 | | |

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on communication circuits of BSNL and Southern Railway with respect to details furnished vide above reference (ii) and (iii) respectively have been computed. The voltage likely to be induced on paralleling communication circuits of BSNL and Southern Railway under Single Line to Ground fault condition are enclosed at Annexure-I and Annexure-II respectively. The screening factors as applicable have been considered.

DG Signals, MoD, vide above reference (iv) (Annexure-III) have issued their No Objection certificate (NOC) for charging of the line.

EPR zone for the proposed substation is mentioned below:

| Name of the proposed Substation | Half diagonal distance, D/2 (mts) | Fault Current I (KA) | Resistance of Earth Mat, R (ohms) | d (mts) at 430 V | d (mts) at 650 V | d (mts) at 7kV | d (mts) at 10kV |
|---|--|----------------------------|--|------------------------|------------------------|-------------------|-----------------------|
| 230/33 kV JSW Tuticorin B Wind Power PSS-B of M/s JSW Renew Energy Ltd at Savlaperi village | 82.54 | 35 | 0.0344 | 149 | 70 | NA | NA |
| 33 kV Wind Power unit substation | 14 | 13.374 | 0.499 | 203 | 130 | NA | NA |

As per the details submitted by BSNL vide reference (ii) above, no telephone exchanges are falling in the EPR zone of the proposed substation.

Taking above into consideration, necessary action regarding issuance of PTCC approval for the subject cited transmission line may be taken under intimation to this office.

Encl.: As above

Director

To,

| 1. | Divisional | BSNL, Inspection Circle,1st Floor, Raj | |
|----|------------------|--|-----------------|
| | Engineer (PTCC), | Bhavan Exchange No. 26, Sardar Patel | |
| | Southern Zone | Road, Guindy, Chennai-600032 | |
| 2 | GM (S&T) | Southern Railway, Headquarter office, | |
| ۷. | GM (S&I) | S&T Branch, Chennai | |
| 2 | M/s JSW Renew | JSW Centre, Bandra Kurla Complex, | For information |
| 3. | Energy Limited | Bandra (East), Mumbai – 400 051 | |

ANNEXURE-I

CEA Case No.: TN-728

Name of the Power line: 33 kV S/C OH line for Feeder No. 4 on RSJ Pole with AL59 Panther conductor and AAAC Dog conductor from

 $220/33\ kV\ JSW\ Tuticorin - B\ S/s$ at Savlaperi village to proposed $33\ kV$

JSW Wind Power unit substation tapping point TUT-155

Map Scale : 1 cm = 500 m

Total Length: 15.0 km

S.R. Value: 15000 Ohm-cm

| | | Length of | | Effective | |
|-------|------------------|------------|----------|-----------|--------|
| | | Parallelis | Mutual | Fault | I.V |
| | | m | Coupling | current | in |
| S.No. | Telecom. Details | in Km. | in Ohms. | in Amps. | Volts. |
| | | | | | |

BSNL: SR-PTCC/STN 5063/05 Dated: 25.08.2023

| 1 | EXGE to DP.0007 |
|----|-------------------------|
| 2 | EXGE to DP.0013 |
| 3 | EXGE to P.21 to DP.2103 |
| 4 | EXGE to P.21 to DP.2109 |
| 5 | EXGE to P.21 to DP.2110 |
| 6 | EXGE to P.21 to DP.2112 |
| 7 | EXGE to P.21 to DP.2123 |
| 8 | EXGE to P.21 to DP.2124 |
| 9 | EXGE to P.21 to DP.2125 |
| 10 | EXGE to P.22 to DP.2204 |
| 11 | EXGE to P.22 to DP.2208 |
| 12 | EXGE to P.23 to DP.2313 |
| 13 | EXGE to P.23 to DP.2314 |
| 14 | EXGE to P.23 to DP.2317 |
| 15 | EXGE to P.24 to DP.2406 |
| 16 | EXGE to P.24 to DP.2407 |
| 17 | EXGE to P.24 to DP.2414 |
| | |

Out of parallelism

I/31763/2023

| 18 | EXGE to P.24 to DP.2415 |
|----|-------------------------|
| 19 | EXGE to P.24 to DP.2419 |
| 20 | EXGE to P.24 to DP.2420 |
| 21 | EXGE to P.24 to DP.2422 |
| 22 | EXGE to P.24 to DP.2424 |
| 23 | EXGE to P.24 to DP.2427 |
| 24 | EXGE to P.24 to DP.2428 |

ANNEXURE-II

CEA Case No.: TN-728

Name of the Power line: 33 kV S/C OH line for Feeder No. 4 on RSJ

Pole with AL59 Panther conductor and AAAC Dog conductor from 220/33~kV JSW Tuticorin – B S/s at Savlaperi village to proposed 33~kV

JSW Wind Power unit substation tapping point TUT-155

Map Scale : 1 cm = 500 m

Total Length: 15.0 km

S.R. Value: 15000 Ohm-cm

| | | Length of | | Effective | |
|-------|------------------|-----------------|--------------------|------------------|-----------|
| | | Parallelis m | Mutual Coupling | Fault current | I.V in |
| S.No. | Telecom. Details | in Km. | in Ohms. | in Amps. | Volts. |
| | | | | | |

| Southern Railway: W.384/3/6/19(TN) Dated: 13.07.2023 | | | | |
|--|------------------------|-------------------------------|--|--|
| 1 | Kovilpatti to Kadambur | Outside IV consideration zone | | |

Tele: 23019746File No.CEA-PS-17-11(14)/45/2023 PCD Division of Signals 1/31763/2023

Signals 7
General Staff Branch
Integrated HQ of MoD, (Army)
DHQ PO, New Delhi – 110011

B/46937/Sigs 7(b)/3321/

04 Jul 2023

JSW Renew Energy Limited

Regd. Office: JSW Centre, Bandra Kurla Complex

Bandra (East), Mumbai-400051

PTCC PROPOSAL FOR CONSTRUCTION OF PROPOSED 33KV DOUBLE CIRCUIT LINE FOR FEEDER NO-SC-04 FROM PROPOSED M/S JSW RENEW ENERGY LTD FOR TOTAL CONNECTIVITY 540MW AT PART OF PROJECT 330MW TUTICORIN-I 230/33KV POOLING SUBSTATIONS WIND POWER PROJECT AT THOOTHUKUDI DISTRICT

- 1. Refer your letter No JSWREL/33kV-PTCC/330MW/SC 04 dt 15 Apr 2023 (copy att).
- 2. **No Objection Certificate (NOC) is accorded** based on inputs provided as per Map sheets received vide your letter mentioned above.
- 3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(SP Choyal)

Lt Col

GSO 1 (Coord)

for ADG T

Enclosures: As above

Copy to :-

The Divisional Engineer (PTCC)
'D' Wing, 3rd Floor, Admn Bdg
Telecom Complex,
Juhu Tara Road,
Santracruz West, Mumbai – 400054

- for information

The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi – 110016

The DET(PTCC), Northern Zone
Bharat Sanchar Nigam Limited
O/o PGM (North), QA & Inspection Circle,
D-Tax Building, Eastern Court, Janpath
New Delhi-110001

PPU. 3144 31107

Sh. Praleek

Central Electricity Authority PCD Division

Sh. Akshay, DD Venz