



सत्यमेव जयते

वैश्व पटुत्वम्
OUR EARTH - ONE FAMILY - ONE FUTURE

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

CEA Case No. : UP-627		
Induced Voltage (IV) calculation for PTCC proposal of Diversion of 1.11 km of 400 kV Anpara-Sarnath (L-5) & Anpara-Mau (L6) D/C Line between Tower No 421 to 424. [Length-1.11 km]-Regd.		
S. No	Reference No.	Dated
(i)	UPPTCL: 1139/ETD-(GZP)	09.08.2023
(ii)	UPPTCL: 1489/ETD-(GZP)	07.10.2023
(iii)	BSNL: DET/PTCC/ND/DV-10230/UP-1128/2023-24	11.08.2023
(iv)	North Eastern Railway: NER-HQ0SndT(TELE)/31/2020-O/O PCSTE/HQ/NER	02.08.2023
(v)	Defense: B/4693/Sigs7(b)/3449	29.09.2023

The PTCC proposal submitted vide reference (i) & (ii) has been examined. The LF induction on Block and Telecom circuits of North Eastern Railway has been computed. The voltage likely to be induced on paralleling Block and Telecom circuits of North Eastern Railway under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors as applicable have been considered. DET (PTCC), NZ, BSNL and DG Signals, MoD have issued No Objection Certificate (NOC) vide reference (iii) & (v) respectively.

Taking above into consideration, necessary action regarding issuance of PTCC approval for the subject cited transmission line might be taken under intimation to this office.

Encl.: As above

ent
13.10.2023
(ल.क.ज.वि.)
Director

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL, O/o PGM(North), QA & Inspection Circle D-Tax Building, Eastern Court, Janpath New Delhi-110001	
2.	GM (S&T)	North Eastern Railway Gorakhpur	Annexure-I
4.	Ex. Engineer UPPTCL	Electricity Transmission Division-I Ghazipur, U.P	Copy for information.

ANNEXURE-I

CEA Case No.: UP-627		Map Scale : 1 cm= 500 m			
Name of the Power line: Diversion of 1.11 km of 400 kV Anpara-Sarnath (L-5) & Anpara-Mau (L6) D/C Line between Tower No 421 to 424.		Total Length : 1.11 km			
		S.R. Value : 50000 Ohm-cm			
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
North Eastern Railway Letter No.: NER-HQ0SndT(TELE)/31/2020-O/O PCSTE/HQ/NER Dated 02.08.2023					
<u>Affected Blocks & Telecom Circuits Details</u>					
400 kV Anpara-Sarnath (L-5) D/C Transmission Line (Total Length- 158.34 km)					
<u>Unnao-Lucknow Section</u>					
1	Varanasi R/s to Rajwari R/s	1.75	0.0002	26200	5
400 kV Anpara-Mau (L6) D/C Transmission Line (Total Length- 262.26 km)					
<u>Unnao-Lucknow Section</u>					
1	Varanasi R/s to Rajwari R/s	1.75	0.0003	15850	5