

I/30623/2023



सत्यमेव जयते



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

Subject: - PTCC clearance for modification/diversion work of 400 kV Dadri-Mandola Transmission Line due to construction of Delhi-Saharanpur Highway-Reg.

Powergrid vide letter dated: 09.09.2023 and e-mail dated 21.09.2023 has requested to review requirement of PTCC NOC/clearance in respect of diversion/modification of existing 400 kV Dadri-Mandola transmission line to extent of 50m due to construction of Delhi-Saharanpur highway by NHAI.

The received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/diversion of the existing 400 kV Dadri-Mandola transmission line between tower no: 121 and 124.

SUN
27/9/23

Chief Engineer

To,
Chief General Manager
Rihand-Delhi HVDC Transmission System
Powergrid, G.B Nagar

Copy to: -

PPS to Member (PS), Central Electricity Authority, Sewa Bhawan, RK Puram-110016