



सत्यमेव जयते

भारत सरकार
Government of India
 विद्युत मंत्रालय
Ministry of Power
 केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
 विद्युत संचार विकास प्रभाग
Power Communication Development Division

Subject: - PTCC clearance for modification/diversion work of 400 kV Meerut-Mandola Transmission Line-I&II due to construction of Delhi-Saharanpur-Dehradun Economic Corridor-Reg.

Powergrid vide letter dated: 18.09.2023 and e-mail dated 21.09.2023 has requested to review requirement of PTCC NOC/clearance in respect of diversion/modification of existing 400 kV Meerut-Mandola transmission line to extent of 290m due to construction of Delhi-Saharanpur-Dehradun economic corridor.

The received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/diversion of the existing 400 kV Meerut-Mandola transmission line-I & II between tower no: 161 and 165.

[Handwritten signature]
21/9/23

Chief Engineer

To,
Dy. General Manager
765/400/220 kV Substation
Powergrid, Meerut

Copy to: -

PPS to Member (PS), Central Electricity Authority, Sewa Bhawan, RK Puram-110016