

I/33096/2024



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

Subject: - PTCC clearance for modification/diversion work of 132 kV Sewa2-Hiranagar Transmission Line due to landslides in the vicinity of Tower No: 54 -Reg.

PGCIL vide Letter No: N2BKT/132kV/DIV/1838 dated: 26.12.2023 has requested to review requirement of PTCC NOC/clearance in respect of diversion/modification of existing 132 kV Sewa2-Hiranagar Transmission Line and has informed that due to landslides in the vicinity of Tower No: 54 maximum lateral diversion of 10 m is done.

In line with the information as provided by PGCIL, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/diversion of the existing 132 kV Sewa2-Hiranagar Transmission Line between towers no: 52 and 55.

This issues with the approval of Chief Engineer.

Deputy Director

**To,
Manager
Powergrid, TLM-Banikhet**