

I/33465/2024



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development

Subject: - PTCC Clearance for Shifting/Diversion work of 220kV D/C Jamalpur-Sangrur Transmission Line to facilitate development of Delhi-Katra Road Highway Corridor under Bharatmala Pariyojana-regd.

BBMB vide email dated 30.01.2024 has requested to review requirement of PTCC NOC/clearance in respect of diversion/ modification of existing 220kV D/C Jamalpur-Sangrur Transmission Line to facilitate development of Delhi-Ludhiana-Amritsar-Katra Road Highway Corridor under Bharatmala Pariyojana by NHAI.

BBMB has informed via letter that existing 02 Nos Towers (129 and 130) have been replaced by 03 new Towers (129, 129A and 130). Further, there is no change in length of line and only height of towers is increased.

On further clarification demanded by PSCD Division, BBMB informed via email that there is no lateral deviation and the modified line is straight line over the existing route. Since the existing line was commissioned on 30.01.1968, so previous PTCC clearance was not available.

In line with the information as provided by BBMB, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/diversion of the existing 220 kV D/C Jamalpur-Sangrur Transmission Line.

Chief Engineer

**To,
Representative BBMB,
Jamalpur Ludhiana**