

I/32929/2024



सत्यमेव जयते

भारत 2023 INDIA
सत्यमेव जयते
ONE EARTH - ONE FAMILY - ONE FUTURE

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

Subject: - PTCC Clearance for Shifting/Diversion work of 220kV D/C Kawas-Navsari line to facilitate construction of Surat Metro Rail project by GMRCL in Bhimrad, Surat -Reg.

PGCIL vide email dated: 05.01.2024 has requested to review requirement of PTCC NOC/clearance in respect of diversion/ modification of existing 220 kV D/C Kawas-Navsari line to facilitate construction of Surat Metro Rail project by GMRCL in Bhimrad, Surat.

PGCIL has informed via email that existing 04 Nos Towers (EXIS 56, EXIS 57, EXIS 58, and EXIS 59) have been replaced by 04 new Towers (PRO 56, PRO 57, PRO 58, PRO 59) to facilitate statutory clearances at railway crossing by raising Tower Heights.

Three new towers (PRO 56, PRO 57 & PRO 59) are coming just under existing line and one tower (PRO 58) is deviates slightly from the existing route. The maximum lateral distance of the new route with the existing route is 9.9mtrs.

In line with the information as provided by PGCIL, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/diversion of the existing 220 kV D/C Kawas-Navsari line.

Director

To,
Senior DGM
Powergrid, TLM,
WR-II, Navsari