

I/33433/2024



सत्यमेव जयते

**भारत सरकार**  
**Government of India**  
**विद्युत मंत्रालय**  
**Ministry of Power**  
**केन्द्रीय विद्युत प्राधिकरण**  
**Central Electricity Authority**  
**विद्युत प्रणाली संचार विकास प्रभाग**  
**Power System Communication Development**

\*\*\*\*\*

**Subject: - PTCC Clearance for Shifting/Diversion work of 400kV D/C Tarapur-Boisar Transmission Line to facilitate construction of Bullet train corridor by NHSRCL in Boisar of Palghar District -regd.**

PGCIL vide email dated 25.01.2024 has requested to review requirement of PTCC NOC/clearance in respect of diversion/ modification of existing 400 kV D/C Tarapur-Boisar Transmission line to facilitate construction of Bullet train corridor by NHSRCL in Boisar of Palghar District and has informed that existing 03 Nos Towers (47, 48 and 49) have been replaced by 05 new Towers (AP1, AP2, AP3, AP4 and AP5) to facilitate statutory clearances from Bullet Train Track by raising Tower Heights resulting in a maximum lateral distance of the new route with the existing route is 65.47mtrs.

In line with the information as provided by PGCIL and original RAC letter no: PTCC/MBI/MRA-1597 dated: 16.04.2005, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/diversion of the existing 400 kV D/C Tarapur-Boisar Transmission line.

**Chief Engineer**

**To,**  
**Sr. GM**  
**TLM (Powergrid)**  
**Boisar**