



भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत संचार विकास प्रभाग Power System Communication Development Division

Subject: - Requirement of PTCC clearance for modification/ diversion work of 765 kV D/C Lakadia - Vadodara Transmission Line due to RoW infringement with newly constructed Ahmedabad-Dholera Expressway -Reg.

Sterlite Power vide Letter No: LVTPL/PMT/DHL-MRTS/23-24/JAN/01 dated: 11.01.2024 has requested to review requirement of PTCC NOC/clearance in respect of diversion/modification of existing 765 kV D/C Lakadia - Vadodara Transmission Line and has informed that due to RoW infringement with newly constructed Ahmedabad-Dholera Expressway, 04 existing tower are abandoned and 04 number of new towers are erected resulting in a maximum lateral diversion of 62 m.

In line with the information as provided by Sterlite and already issued PTCC approval vide letter No. QA&Insp./MBI/PTCC/GUJ -2823 (Request No-200897, Workorder NoWGJ220720202823) dated 09.02.2022, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/ diversion of the existing 765 kV D/C Lakadia - Vadodara Transmission Line between towers no: 466 and 469.

This is issued with the approval of Chief Engineer.

Deputy Director

To, Authorized Personal Sterlite Power Transmission Limited DLF Cyber Park, 9th Floor, Sector 20, Gurugram- 122 008