



भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत संचार विकास प्रभाग

Power Communication Development Division

CEA Case No. : AND-722							
Induced Voltage (IV) calculation in respect of PTCC proposal for erection of 220 kV SC/DC line from 220/11KV Krishnagiri SS to 220/11KV Nansuralla in Kurnool district(23.94 km) - regd.							
S. No	Reference No.	Dated					
(i)	TCAPL: CE/Projects/SE-220&132/EE-1/DEE-4/F.KRIS-NANS/	26.12.2022					
	/D.No.150/22						
(ii)	BSNL: SR-PTCC/SAP4781/06	21.03.2023					
(iii)	South Central Railway: SG.85/4/3/ PTCC/SCR/2022-23/AP-15 RTD	27.01.2023					
(iv)	Defense: B/46937/Sigs 7(b)/3397	06.09.2023					

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on Block and Telecom circuits of BSNL and South Central Railway with respect to details furnished vide above reference (ii) & (iii) respectively has been computed. The voltage likely to be induced on paralleling Block and Telecom circuits of BSNL and South Central Railway under Single Line to Ground fault condition are enclosed at Annexure-I & Annexure –II respectively

DG Signals, Mod and have issued No Objection Certificate (NOC) vide reference (iv) (enclosed as Annexure III)

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office.

Encl.: As above

Chief Engineer

To,

1.	Divisional	BSNL, Inspection Circle, 2 nd Floor, Sanchar
	Engineer (PTCC),	Complex, WMS Compound, Jayanagar 5 th
	Southern Zone	Block, 9 th Main, 47 th Cross ,Bangalore-
		560041
2.	GM (S&T)	South Central Railway, Office of Principal
		Chief Signal & Telecom Engineer, 7th Floor,
		Rail Nilayam, Secunderabad – 500 025
3.	Chief Engineer	APTransco, Vidyut Soudha,
	Projects	Gunadala,Vijayawada-520004,Andhra
		Pradesh

ANNEXURE-I

CEA Ca	ase No.: AND-722	Map Scale : 1 cm= 500 m Total Length : 23.94 km				
220 kV SC/DC line from 220/11KV Krishnagiri SS to 220/11KV Nansuralla in Kurnool district(23.94 km) - regd.		S.R. Value : 50000 ohm-cm				
		Length of Parallelis m	Mutual Coupling	Effective Fault current	I.V in	
S.No.	Telecom. Details	in Km.	in Ohms.	in Amps.	Volts.	
BSNL Letter No.: SR-PTCC/SAP4781/06 Date: 21.03.2023						
1	Kamavarapukota Exg to DP 01	IV less than 430V				
2	Kamavarapukota Exg to DP 02	IV less than 430V				
3.	Kamavarapukota Exg to DP 03	IV less than 430V				

I/33228/2024 <u>ANNEXURE-II</u>

220 kV	ase No.: AND-722 SC/DC line from 220/11KV Krishnagiri SS t lla in Kurnool district(23.94 km) - regd.	o 220/11KV	Total Length	: 1 cm= 500 m : 23.94 km : 50000 ohm-cm		
S.No.	Telecom. Details	Length of Parallelis m in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.	
South Central Railway Letter No.: SG.85/4/3/ PTCC/SCR/2022-23/AP-15 RTD Date: 27.01.2023						
1	Ullindakonda(UKD) - Veldurti(VDI)	Out of parallelism				
2	Veldurti(VDI) - Bogolu(BVO)	Out of parallelism				