

I/33153/2024



सत्यमेव जयते



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power System Communication Development
Division

Subject: - PTCC clearance for modification/diversion work of 765 kV S/C Gwalior-Jaipur/Phagi (RVPN) Ckt-1 Transmission Line due to RoW infringement with newly constructed Economic Corridor under Bharatmala Pariyojana -Reg.

PGCIL vide Letter No: NR1/765 kV/PG-1/DIV/PTCC/01/180 dated: 15.01.2024 and e-Mail dated 19.01.2024 has requested to review requirement of PTCC NOC/clearance in respect of diversion/modification of existing 765 kV S/C Gwalior-Jaipur/Phagi (RVPN) Ckt-1 Transmission Line and has informed that due to RoW infringement with newly constructed economic corridor under Bharatmala Pariyojana, 01 existing tower i.e. Tower No: 674 are abandoned and 02 number of new towers are erected resulting in a maximum lateral diversion of 10 m.

In line with the information as provided by PGCIL, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/diversion of the existing 765 kV S/C Gwalior-Jaipur/Phagi (RVPN) Ckt-1 Transmission Line between towers no: 673 and 675.

This is issued with the approval of Chief Engineer.

Deputy Director

To,
Deputy General Manager
Powergrid, Jaipur