

I/32803/2024



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

CEA Case No. : KNK-1041		
Induced Voltage (IV) Calculation for PTCC proposal for 33 kV S/C OH line for Feeder No. 5 on RSJ Pole with AL59 Dog conductor and AL59 TW (Eco) Panther conductor from 220/33 kV Vena Energy Vidyuth Private Limited S/s at Jumalapura Village, Kushtagi to proposed 33 kV unit substation (Length: 9.09 km)		
S. No	Reference No.	Dated
(i)	VENA/33kVPTCC/FED05	30.05.2023
(ii)	BSNL: SR-PTCC/SKT5094/02	19.12.2023
(iii)	South Western Railway: SG/SWR/PTCC/KNK1041/2613	06.11.2023
(iv)	Defense: B/46937/Sigs 7(b)/3432	01.09.2023

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on communication circuits of BSNL with respect to details furnished vide above references (ii) have been computed. The voltage likely to be induced on paralleling communication cables of BSNL under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors as applicable have been considered. South Western Railway and DG Signals, MoD have issued No Objection Certificate (NOC) vide reference (iii) and (iv) (enclosed as Annexure-II) respectively.

EPR Zones for proposed substations are mentioned below.

Name of the proposed SS	Half Diagonal Distance, D/2 (mts)	Fault Current, I (kA)	Resistance of earthmat, R (Ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7 kV	d (mts) at 10 kV
220/33 kV Vena Energy Vidyuth Private Limited S/s at Jumalapura Village, Kushtagi	113.1	28	0.2032	1383	877	NA	NA
33/0.69 kV Unit substation for Feeder No. 5	12.7	20	0.6184	353	229	10	3

As per the details submitted by BSNL vide reference (ii) above, no telephone exchange is falling in the EPR zone of the proposed substations.

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office.

Encl.: As above

Director

I/32803/2024

To,

1.	Divisional Engineer (PTCC)	O/o CGM, QA & Inspection circle, 2 nd Floor, Sanchar complex, WMS compound, Jayanagar, 5 th block, 9 th main, 47 th cross, Bengaluru- 560 041	
2.	M/s Vena Energy Vidyuth Private Limited	2/1, First Floor, Embassy Icon Annexe Infantry Road, Bengaluru	Copy for information

I/32803/2024

ANNEXURE-I

CEA Case No.: KNK-1041					
Name of the Power line: 33 kV S/C OH line for Feeder No. 5 on RSJ Pole with AL59 Dog conductor and AL59 TW (Eco) Panther conductor from 220/33 kV Vena Energy Vidyuth Private Limited S/s at Jumalapura Village, Kushtagi to proposed 33 kV unit substation		Map Scale : 1 cm= 500 m			
		Total Length : 9.09 km			
		S.R. Value : 20000 Ohm-cm			
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
BSNL Letter No: SR-PTCC/SKT5094/02 Date: 19.12.2023					
I	Tavaragera Telephone Exchange				
1	Exchange to Menadhal road (T-T1)	Out of parallelism			
2	Exchange to Kushtagi road (T-T2)				
3	Exchange to KEB office (T-TA)				
4	KEB office to Temple road (TA-T3)				
5	Exchange to Police Station (T-T4)				
6	KEB office to Killharhati road (TA-T5)				
7	KEB office to Sindhanoor road (TA-T6)				
II	Hiremanpura Telephone Exchange				
1	Exchange to Navalhalli road (H-H1)	IV less than 430 V			
2	Exchange to Gumagera road (H-H2)				
3	Exchange to MG road (H-H2)				

I/32803/2024

ANNEXURE-II

Tele : 23019746

Directorate General of Signals
 Signals - 7
 General Staff Branch
 Integrated HQ of MoD, (Army)
 DHQ PO, New Delhi – 110011

KNK-1041

B/46937/Sigs 7(b)/3432

01 Sep 2023

Vena Energy Vidyuth Private Limited
 2/1, 1st Floor, Embassy Icon Annexe,
 Infantry Road, Bangalore-560001
 Karnataka, India

**PTCC PROPOSAL FOR LAYING OF 33KV OVERHEAD LINE FOR
 FEEDER NO. 5 FOR WIND POWER PROJECT UNDER SECI BID IN KOPPAL
 DISTRICT, KARNATAKA (LENGTH: 9.09 KM)**

1. Refer your letter No. Nil dt 19 Jun 2023 (copy att).
2. **No Objection Certificate (NOC) is accorded** based on inputs provided as per Map sheets received vide your letter mentioned above.
3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.



(SK Sharma)
 Lieutenant Colonel
 General Staff Officer Grade 1 (Communication)
 for Additional Director General (Telecommunication)

Enclosures : As aboveCopy to :-

The Divisional Engineer (PTCC)
 'D' Wing, 3rd Floor, Admn Bdg
 Telecom Complex,
 Juhu Tara Road,
 Santracruz West, Mumbai – 400054

- for information

The Director (PTCC), CEA
 Power Communication Development Division
 NRPC Complex, 18-A Shaheed Jeet Singh Marg
 Katwaria Sarai, New Delhi – 110016

The DET(PTCC), Northern Zone
 Bharat Sanchar Nigam Limited
 O/o PGM (North), QA & Inspection Circle,
 D Tax Building, Eastern Court, Janpath
 New Delhi-110001

Central Electricity Authority
 PCD Division

Diary No. 310

Date. 17/9/23

Sh. Anshu (DD)
 20/9

PPU. 31814
 05/10

Sh. Prateek