

भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत प्रणाली संचार विकास प्रभाग

Power System Communication Development Division

| CEA Case No.: MP-510 | | | | | | | | |
|--|--|------------|--|--|--|--|--|--|
| Induced Voltage (IV) calculation for PTCC proposal of 220 kV S/C Transmission Line from 400/220 kV Pachora S/s to 220/33 kV Unit-5 S/s [Length- 32.206 km] - Regd. | | | | | | | | |
| S. No | Reference No. | Dated | | | | | | |
| (i) | RUMS: F/RUM/2022/REP/05-059/264 | 15.06.2023 | | | | | | |
| (ii) | RUMS e-mail | 13.02.2024 | | | | | | |
| (iii) | BSNL: PTCC/WR/2023-24/MP-820 | 05.12.2023 | | | | | | |
| (iv) | Western Railway: SG.158/28/10/L-287 | 30.01.2024 | | | | | | |
| (v) | West Central Railway: WCR/N-HQ/120PTCC-COO-T-50-Pt-IIICase-398(Unit-5) received via RUMS e-Mail dated 21.02.2024 | 16.02.2024 | | | | | | |
| (vi) | Defense: B/46937/Sigs7(b)/3438 | 14.11.2023 | | | | | | |

The PTCC proposal submitted vide reference (i) and (ii) has been examined. DET (WZ), BSNL vide reference (iii), Western Railway vide reference (iv), West Central Railway vide reference (v) and DG Signals, MoD vide reference (vi) have issued No Objection Certificate (NOC) for charging of the line.

EPR Zones for proposed substations are mentioned below:

| | To 10 | | | | | | |
|-------------|-----------|------------|---------------|----------|---------|---------|---------|
| Name of the | Half | Fault | Resistance | d (mts) | d (mts) | d (mts) | d (mts) |
| proposed SS | Diagonal | Current, I | of earth mat, | at 430 V | at 650 | at 7 kV | at 10 |
| | Distance, | (kA) | R (Ohms) | | V | | kV |
| | D/2 (mts) | | | | | | |
| 220/33 kV | 130 | 40 | 0.11 | 1200 | 750 | NA | NA |
| Unit-5 S/s | | | | | | | |
| 400/220 kV | 73 | 44.1 | 0.22 | 3730 | 2409 | 67 | NA |
| Pachora S/s | | | | | | | |

As per the Telecom Details submitted by BSNL vide above reference (iii) no telephone exchange of BSNL is falling within the EPR zone of proposed Substations.

Taking above into consideration, necessary action regarding issuance of PTCC approval for the subject cited transmission line might be taken under intimation to this office.

Encl.: As above

Chief Engineer

To,

| 1. | Divisional QA & Inspection circle, | | |
|----|------------------------------------|---------------------------------------|-----------------|
| | Engineer (PTCC), | 1st floor, D- wing, BSNL Admin Bldg., | |
| | Western Zone | Junu Tara Road, Santa Cruz (West), | |
| | | Mumbai-400054 | |
| | Executive | Urja Bhjawan, Shivaji Nagar | |
| 2. | Engineer | Bhopal | For Information |
| | RUMS Ltd. | | |