



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development Division

CEA Case No.: RAJ-717		
Induced Voltage (IV) calculation for PTCC proposal of 220 kV S/C line on S/C, D/C & M/C tower from 220/33 kV PSS of M/s RSRPL to 765/400/220 kV Fatehgarh-III GSS of PGCIL (Length: 18.041 km)		
S. No	Reference No.	Dated
(i)	RSRPL/PTCC/01 (received on 03.07.2023)	09.05.2023
(ii)	CEA: I/32730/2023	28.12.2023
(iii)	Defense: B/46937/Sigs7(b)/3435	24.01.2024

Vide reference (ii) above, it was recommended to issue provisional PTCC approval for the subject cited line considering the urgent request for charging of the line by M/s RSRPL.

Now DG Signals, MoD vide reference (iii) above has accorded their No Objection Certificate (NOC) for charging of the subject cited transmission line.

In view of the above, necessary action may be taken for issuance of final PTCC approval for the subject transmission line under intimation to this office.

This issues with the approval of Chief Engineer.

Deputy Director

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL, O/o GM (North), QA & Inspection Circle D-Tax Building, Eastern Court, Janpath New Delhi-110001	
2.	M/s Renew Surya Roshni Private Limited	Renew Hub, Commercial Block-1, Zone-6, Golf Course Road, DLF City Phase-V, gurugram – 122 009	Copy for information