

I/33154/2024



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
केन्द्रीय विद्युत प्राधिकरण  
Central Electricity Authority  
विद्युत प्रणाली संचार विकास प्रभाग  
Power System Communication Development Division

\*\*\*\*\*

**Subject: - PTCC clearance for modification/diversion work of 400 kV D/C Rampur-Nalagarh TL of POWERGRID due to land settlement caused by heavy rainfall in Himachal Pradesh – regd.**

PGCIL vide letter no.-NR2NLG/Rerouting-334/CEA/305 dated: 21.12.2023 has requested to review requirement of fresh PTCC approval/ NOC in respect of diversion/modification of existing 400 kV D/C Rampur-Nalagarh TL of POWERGRID due to land settlement caused by heavy rainfall in Himachal Pradesh in July-August'23. PGCIL has informed that existing Tower No. 334 is being replaced with new tower i.e. AP1 resulting in maximum lateral deviation of approximately 50 meters.

In line with the information provided by PGCIL, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/diversion of the existing 400 kV D/C Rampur-Nalagarh TL.

This issues with the approval of Chief Engineer.

**Deputy Director**

**To,  
Chief Manager  
Powergrid, Nalagarh**