

भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत संचार विकास प्रभाग

Power Communication Development Division

CEA Cas	e No.: TN-734			
Induced Voltage (IV) Calculation for PTCC proposal of 33 kV D/C OH line for Feeder No. 6 & 7 on RSJ Pole with AL59 Panther conductor and AAAC Dog conductor from 220/33 kV JSW Tuticorin – B S/s at Savlaperi village to proposed 33 kV JSW Wind Power unit substation tapping point TUT-460 (Length: 26.30 km)				
S. No	Reference No.	Dated		
(i)	JSWREL/33kV-PTCC/330 MW/DC-03	15.04.2023		
(ii)	BSNL: SR-PTCC/STN 5050/04	25.08.2023		
(iii)	Southern Railway: W.384/3/6/25(TN)	12.07.2023		
(iv)	Defense: B/46937/Sigs 7(b)/3316	04.07.2023		

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on communication circuits of BSNL and Southern Railway with respect to details furnished vide above reference (ii) and (iii) respectively have been computed. The voltage likely to be induced on paralleling communication circuits of BSNL and Southern Railway under Single Line to Ground fault condition are enclosed at Annexure-I and Annexure-II respectively. The screening factors as applicable have been considered.

DG Signals, MoD, vide above reference (iv) (Annexure-III) have issued their No Objection certificate (NOC) for charging of the line.

EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
230/33 kV JSW Tuticorin B Wind Power PSS-B of M/s JSW Renew Energy Ltd at Savlaperi village	82.54	35	0.0344	149	70	NA	NA
33 kV Wind Power unit substation	14	13.374	0.583	240	154	2	NA

1/32961/2024

As per the details submitted by BSNL vide reference (ii) above, no telephone exchanges are falling in the EPR zone of the proposed substation.

Taking above into consideration, necessary action regarding issuance of PTCC approval for the subject cited transmission line may be taken under intimation to this office.

Encl.: As above

Director

To,

1.	Divisional	BSNL, Inspection Circle,1st Floor, Raj	
	Engineer (PTCC),	Bhavan Exchange No. 26, Sardar Patel	
	Southern Zone	Road, Guindy, Chennai-600032	
2.	GM (S&T)	Southern Railway, Headquarter office, S&T Branch, Chennai	
-	NA TOWN D		F : 6 4:
3.	M/s JSW Renew	JSW Centre, Bandra Kurla Complex,	For information
٥.	Energy Limited	Bandra (East), Mumbai – 400 051	

ANNEXURE-I

CEA Case No.: TN-734

Name of the Power line: 33 kV D/C OH line for Feeder No. 6 & 7 on RSJ Pole with AL59 Panther conductor and AAAC Dog conductor from 220/33 kV JSW Tuticorin – B S/s at Savlaperi village to proposed 33 kV JSW Wind Power unit substation tapping point TUT-460 (Length: 26.30

km)

Map Scale : 1 cm = 500 m

Total Length: 26.3 km

S.R. Value: 15000 Ohm-cm

		Length of		Effective	
		Parallelis	Mutual	Fault	I.V
		m	Coupling	current	in
S.No.	Telecom. Details	in Km.	in Ohms.	in Amps.	Volts.

	BSNL: SR-PTCC/STN 5	050/04 Dated	: 25.08.2023				
KAYA	THAR TELEPHONE EXCHANGE						
1	EXGE to DP.0003						
2	EXGE to DP.0006						
3	EXGE to DP.0012						
4	EXGE to DP.0023						
5	EXGE to P.22 to DP.2208						
6	EXGE to P.22 to DP.2219	Out of parallelism					
7	EXGE to P.22 to DP.2233						
8	EXGE to P.22 to DP.2247						
9	EXGE to P.25 to DP.2503						
10	EXGE to P.25 to DP.2522						
11	EXGE to P.25 to DP.2539						
12	EXGE to P.25 to DP.2549						
13	EXGE to P.25 to DP.2533						
NALA	TTINPUTHUR TELEPHONE EXCHANGE	I					
1	EXGE to DP.0007						
2	EXGE to DP.0013			11.17.			
3	EXGE to P.21 to DP.2103	-	Out of p	arallelism			

1/32961/2024

4	EXGE to P.21 to DP.2109	
5	EXGE to P.21 to DP.2110	
6	EXGE to P.21 to DP.2112	
KADAN	MBUR TELEPHONE EXCHANGE	
1	EXGE to P.40 to DP.4004	Out of morellations
2	EXGE to P.41 to DP.4118	Out of parallelism

ANNEXURE-II

CEA Case No.: TN-734

Name of the Power line: 33 kV D/C OH line for Feeder No. 6 & 7 on RSJ Pole with AL59 Panther conductor and AAAC Dog conductor from 220/33 kV JSW Tuticorin – B S/s at Savlaperi village to proposed 33 kV JSW Wind Power unit substation tapping point TUT-460 (Length: 26.30

Map Scale : 1 cm = 500 m

Total Length: 26.3 km

S.R. Value: 15000 Ohm-cm

S.No.	Telecom. Details	Length of Parallelis m in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
1	Southern Railway: W.384/3/	6/25(TN) date	ed 12.07.2023		
1	Kovilpatti to Kadambur	4.3	0.0167	9880	165
2	Kadambur to Vanchi Maniyachchi	Out of parallelism			

1/32961/2024

Tele: 23019 File No.CEA-PS-17-11(14)/51/2023-PGD Division General of Signals

Signals 7
General Staff Branch
Integrated HQ of MoD, (Army)
DHQ PO, New Delhi – 110011

B/46937/Sigs 7(b)/3316/

Olp Jul 2023

JSW Renew Energy Limited Regd. Office: JSW Centre, Bandra Kurla Complex Bandra (East), Mumbai-400051

PTCC PROPOSAL FOR CONSTRUCTION OF PROPOSED 33KV DOUBLE CIRCUIT LINE FOR FEEDER NO-DC: 06&07 FROM PROPOSED M/S JSW RENEW ENERGY LTD FOR TOTAL CONNECTIVITY 540MW AT PART OF PROJECT 330MW TUTICORIN-I 230/33KV POOLING SUBSTATIONS WIND POWER PROJECT AT THOOTHUKUDI DISTRICT

- 1. Refer your letter No JSWREL/33kv-PTCC/DC-03 dt 15 Apr 2023 (copy att).
- 2. **No Objection Certificate (NOC) is accorded** based on inputs provided as per Map sheets received vide your letter mentioned above.
- 3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(SP Choyal)

Lt Col

GSO 1 (Coord) for ADG T

Enclosures: As above

Copy to:-

The Divisional Engineer (PTCC)
'D' Wing, 3rd Floor, Admn Bdg
Telecom Complex,
Juhu Tara Road,
Santracruz West, Mumbai – 400054

- for information

The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi – 110016

The DET(PTCC), Northern Zone
Bharat Sanchar Nigam Limited
O/o PGM (North), QA & Inspection Circle,
D Tax Building, Eastern Court, Janpath
New Delhi-110001

Central Electricity Authority
PCD Division

8h. Akishang, DD Ohn 27/ PPU. 31274 3167 St. Prateck