



**भारत सरकार**  
**Government of India**  
**विद्युत मंत्रालय**  
**Ministry of Power**  
**केन्द्रीय विद्युत प्राधिकरण**  
**Central Electricity Authority**  
**विद्युत प्रणाली संचार विकास प्रभाग**  
**Power System Communication Development**

\*\*\*\*\*

**Subject: - PTCC clearance for modification/diversion work of 400 kV D/C Kaithal - Hisar Transmission Line due to construction of Delhi-Katra-Amritsar Green Expressway by NHAI -regd.**

PGCIL vide letter reference no.- NR1/KHTL/PTCC/06 dated 30.10.2023 and e-Mail dated 14.05.2024 has requested to review requirement of fresh PTCC clearance/ NOC in respect of diversion/ modification of existing 400 kV D/C Kaithal - Hisar Transmission Line (erstwhile 400 kV D/C Nalagarh-Hisar Transmission Line) due to construction of Delhi-Katra-Amritsar Green Expressway by NHAI.

PGCIL vide above letter has informed that existing 02 Towers (TW-48 and TW-49) are dismantled and three new towers are erected between Tower No 47 and 50 resulting in a maximum lateral deviation of approx. 50 m from the existing route.

In line with the information submitted by PGCIL and PTCC approval issued vide BSNL letter No. PTCC(T)/DV-7262/PJ-581 dated 23.04.1999, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/ diversion of the existing 400 kV D/C Kaithal - Hisar Transmission Line.

**Chief Engineer**

**To,**  
**Sr. DGM, Powergrid**  
**400/220 kV S/s, Hisar**