



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development

Subject: - PTCC clearance for modification/diversion work of 400 kV D/C Kolar - Hoody Transmission Line due to construction of Bangalore-Chennai Expressway by NHAI under Bharatmala Pariyojana-regd.

PGCIL vide letter reference no.- SRTS-II/Kolar/TL/NHAI-Diversion/June/2024 dated 23.05.2024 and e-Mail dated 23.05.2024 has requested to review requirement of fresh PTCC clearance/ NOC in respect of diversion/ modification of existing 400 kV D/C Kolar - Hoody Transmission Line due to construction of Bangalore-Chennai Expressway by NHAI.

PGCIL vide above letter has informed that existing 01 Nos Tower (TW-101) is dismantled and two new towers are erected (TW-100A and TW-101) resulting in a maximum lateral deviation of approx. 37 m from the existing route.

In line with the information submitted by PGCIL and PTCC approval issued vide BSNL letter No. SR/PTCC/KNK/1577/9 dated 03.07.2002, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/ diversion of the existing 400 kV D/C Kolar - Hoody Transmission Line.

Chief Engineer

To,
Sr. DGM, Powergrid
HVDC, Kolar