



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development
Division

Subject: - PTCC clearance for modification/diversion work of 400 kV D/C Bassi-Sikar Transmission Line to facilitate construction of Jaipur - Bandikui National Highway by NHAI-regd.

PGCIL vide email dated 03.05.2024 has requested to review requirement of fresh PTCC clearance/ NOC in respect of diversion/ modification of existing 400 kV D/C Bassi-Sikar Transmission Line to facilitate construction of Jaipur - Bandikui National Highway by NHAI.

PGCIL vide above email has informed that existing 01 Nos Tower (TW-431) is being replaced by 02 new Towers (TW-431 and TW-431/A) resulting in a maximum lateral deviation of approx. 24 m from the existing route. Further, diverted section is within same corridor/have the same ROW of existing ROW.

In line with the information submitted by PGCIL, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/ diversion of the existing 400 kV D/C Bassi-Sikar line.

Chief Engineer

**To,
Senior General Manager
PGCIL, Bassi**