

I/34576/2024



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development

Subject: - PTCC clearance for modification/diversion work of 765 kV S/C Bina-Indore Transmission Line to facilitate construction of new railway tracks near Kurawar, Rajgarh (M.P.)-regd.

PGCIL vide emails dated 05.02.2024 and 01.03.2024 has requested to review requirement of fresh PTCC clearance/ NOC in respect of diversion/ modification of existing 765 kV S/C Bina-Indore Transmission Line to facilitate construction of new railway tracks near Kurawar, Rajgarh (M.P.)

PGCIL vide email dated 05.02.2024 has informed that existing 04 Nos Towers (TW-433, TW-434, TW-435 and TW-436) are being replaced by 05 new Towers (TW-433, TW-434, TW-434A, TW-435, and TW-436) resulting in a maximum lateral deviation of approx. 250 m from the existing route.

In line with the information submitted by PGCIL and PTCC approval issued vide BSNL letter No. IC/MBI/PTCC/MP-295 dated 28.02.2012, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/ diversion of the existing 765 kV S/C Bina-Indore line.

Chief Engineer

To,
Chief General Manager
Powergrid, Bhopal
E-mail: ak.chourasia@powergrid.in