

# भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत प्रणाली संचार विकास प्रभाग Power System Communication Development

CEA Case No. : GUJ-819					
Induced Voltage (IV) calculation for PTCC proposal of 220 kV S/C line from 220kV					
Wankaner SS to Wankaner Kallway ISS Switchyard(0.68 km)- regd.   S No Reference No					
(i)	GETCO: CE(Project)/SE(Planning)/8634	07.10.2021			
(ii)	BSNL: IC/MBI/PTCC/WGJ011120213610	11.05.2022			
(iii)	Western Railway: SG.158/28/12/1178	28.10.2021			
(iv)	Defense: B/46937/Sigs 7(b)/2616	16.12.2021			

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on communication circuits of BSNL and Western Railway with respect to details furnished vide above reference (ii) & (iii) respectively have been computed. The voltage likely to be induced on paralleling communication cables of BSNL and Western Railway under Single Line to Ground fault condition are enclosed at Annexure-I & II respectively. The screening factors as applicable have been considered. Vide reference (iv) above, DG Signals, MoD has issued No Objection Certificate (NOC) (enclosed as Annexure-III).

	<b>.</b>						
Name of the	Half	Fault	Resistance	d (mts)	d (mts)	d (mts)	d (mts)
proposed SS	Diagonal	Current, I	of earthmat,	at 430 V	at 650	at 7 kV	at 10
• •	Distance,	(kA)	R (Ohms)		V		kV
	D/2 (mts)	~ /	~ /				
220 kV	80.43	28	0.3	1491	959	16	NA
Wankaner							
GIS SS							
220kV	55.9	28	0.4	1400	907	33	7
Wankaner							
Railway TSS							

EPR Zones for proposed substations are mentioned below.

As per the details submitted by BSNL vide reference (ii) above, no telephone exchanges are falling in the EPR zone of the proposed substation.

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office.

Encl.: As above

1	6
	ιυ,

1.	Divisional	QA & Inspection circle, 1 <sup>st</sup> floor, D- wing,	
	Engineer (PTCC),	BSNL Admin Bldg., Junu Tara Road, Santacruz	
	Western Zone	(West), Mumbai-400054	
2.	GM (S&T)	Western Railway, O/o PCSTE, S&T Dept., 5th	
		Floor, Station Building, Churchgate, Mumbai -	
		400020	
	Chief Engineer	GETCO, Sardar Patel Vidyut Bhavan, Race	Conv. for information
3.	(Project)	Course, Vadodara - 390007	Copy for information

#### 1/40233/2024

٦

### ANNEXURE-I

<b>CEA Case No.:</b> GUJ-819 <b>Name of the Power line</b> : 220 kV S/C line from 220kV Wankaner SS to Wankaner Railway TSS Switchyard			Map Scale : 1 cm= 500 m Total Length : 0.68 km S.R. Value : 15000 Ohm-cm			
S.No.	Telecom. Details	Length of Parallelis m in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.	
	BSNL Letter No IC/MBI/PTC	CC/WGJ01112	20213610 Dat	e: 11.05.2022	<u> </u>	
1	Wankaner EXCHANGE					
1A	Wankaner Exch. – Roy Side- Local 400P					
2A	Wankaner Exch. – Roy Side- Local 800P	IV less than 430V				
<b>3A</b>	Wankaner ExchLocal 400P					
<b>4</b> A	Wankaner Exch. – Amarsar Side- Local 300P	-				
2	2 Mobile Tower					
T1	Chandrapur Mob Tower	Out of Parallelism				
T2	Bhatiya Mob Tower					
T3	Vishipar Mob Tower					
T4	Shradhha Complex mob Tower					

#### 1/40233/2024

### **ANNEXURE-II**

<b>CEA Case No.:</b> GUJ-819 <b>Name of the Power line</b> : 220 kV S/C line from 220kV Wankaner SS t Wankaner Railway TSS Switchyard			Map Scale : 1 cm= 500 m Total Length : 0.68 km S.R. Value : 15000 Ohm-cm			
		Length of Parallelis m	Mutual Coupling	Effective Fault current	I.V in	
S.No.	Telecom. Details	in Km.	in Ohms.	in Amps.	Volts.	
WESTERN RAILWAY Letter No SG.158/28/12/1178 Date: 28.10.2021						
1	Makansar-Wankaner	0.1	0.00003	3295	0.1	
2	Wankaner-Lunsariya	0.4	0.00015	20652	3	
3	Wankaner-Amarsar	0.15	0.000015	11530	0.2	
4	Amarsar- Sindhavadar	Out of Parallelism				
5	Daladi - Lunsariya		Out of F	Parallelism		

GUT-819

Tele: 23019746

Directorate General of Signals Signals 7 General Staff Branch Integrated HQ of MoD, (Army) DHQ PO, New Delhi – 110011

B/46937/Sigs 7(b)/2616/

Dec 2021

Chief Engineer (Project) Gularat Energy Transmission Corporation Ltd Sardar Patel Vidyut Bhawan Race Course, Vadodara – 390 007

## SUBMISSION OF PROPOSALS FOR HV/EHV TRANSMISSION LINES OF GETCO FOR PTCC APPROVAL OF 220KV LINE FROM 220KV WANKANER (GIS) S/S TO WANKANER RAILWAY TSS SWITCHYARD WITH 220KV S/C 1CX1200 SQ MM U/G CABLE

1. Refer your letter No CE(Project)/SE(Planning)/8634 dt 07 Oct 2021 (copy att).

2. No Objection Certificate (NOC) is accorded based on inputs provided as per Map sheets received vide your letter mentioned above.

3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(Rakesh Kumar) Lt Col GSO 1 (Comn) for SO-in-C

Enclosures : As above

Copy to :-

The Director (PTCC), CEA Power Communication Development Division NRPC Complex, 18-A Shaheed Jeet Singh Marg Katwaria Sarai, New Delhi – 110016

The-DET(PTCC), Northern Zone O/o PGM (North), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath New Delhi-110001 - for information