



सत्यमेव जयते

**भारत सरकार**  
**Government of India**  
**विद्युत मंत्रालय**  
**Ministry of Power**  
**केन्द्रीय विद्युत प्राधिकरण**  
**Central Electricity Authority**  
**विद्युत प्रणाली संचार विकास प्रभाग**  
**Power System Communication Development**

\*\*\*\*\*

**Subject: - PTCC clearance for modification/diversion work of 220 kV D/C Kawas-Vav Transmission Line to facilitate construction of Akshardham temple by BAPS-regd.**

PGCIL vide email dated: 18.05.2024 has requested to review requirement of fresh PTCC clearance/ NOC in respect of diversion/ modification of existing 220 kV D/C Kawas-Vav Transmission Line to facilitate construction of Akshardham temple by BAPS.

PGCIL vide above email has informed that existing 4 Nos Towers (TW-50 to TW-53) are being replaced by 7 Nos new Towers (TW-50 to TW-53, TW-53A, TW-53B and TW-53C) resulting in a maximum lateral deviation of approximately 227 m from the existing route. Since Old PTCC approval is not available with PGCIL, therefore, PGCIL has given an undertaking that in case of any damage to telecom assets and personnel of Railway, BSNL and Defense due to said diversion, PGCIL will bear the cost.

In line with the information submitted by PGCIL, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/ diversion of the existing 220 kV D/C Kawas-Vav line.

**Chief Engineer**

**To,**  
**Chief General Manager**  
**Powergrid,**  
**WR-II, Vadodara**