



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development

Subject: - PTCC clearance for modification/diversion work of 400 kV S/C Korba-Bhatapara Transmission Line to facilitate construction of Bilaspur-Urga section of NH-130A Expressway by NHAI under Bharatmala Pariyojana-regd.

PGCIL vide email dated: 13.05.2024 has requested to review requirement of fresh PTCC clearance/ NOC in respect of diversion/ modification of existing 400 kV S/C Korba-Bhatapara Transmission Line to facilitate construction of Bilaspur-Urga section of NH-130A Expressway by NHAI under Bharatmala Pariyojana (Raipur-Dhanbad Economic Corridor) in the State of Chhattishgarh.

PGCIL vide above email has informed that existing 2 Nos Towers (TW-181 and TW-182) are being replaced by 3 Nos new Towers (TW-181, TW-182-A, TW-182) resulting in a maximum lateral deviation of approximately 134m from the existing route.

PGCIL has given an undertaking that there is no overhead telecommunication lines, railway lines in the 8km radius of diverted route of 400kV S/C Korba-Bhatapara line. PGCIL has also informed that original PTCC clearance of 400kV S/C Korba-Bhatapara Transmission Line is not traceable since the line is very old.

In line with the information submitted by PGCIL, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/ diversion of the existing 400 kV S/C Korba-Bhatapara Transmission Line. .

Chief Engineer

**To,
Chief General Manager
PGCIL, Korba**