



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development

Subject: - PTCC clearance for modification/diversion work of 400 kV S/C Korba - Bhilai Transmission Line Ckt-1 due to collision of truck with one tower - regd.

PGCIL vide e-Mail dated 27.05.2024 has requested to review requirement of fresh PTCC clearance/ NOC in respect of diversion/ modification of existing 400 kV S/C Korba - Bhilai Transmission Line due to collision of truck with one tower (TW- 198 A).

PGCIL vide above email has informed that existing 02 Towers (TW-197A and TW-198 A) are dismantled and three new towers are erected (TW- 197 B, TW- 198/A and TW-198/B) resulting in a maximum lateral deviation of approx. 33 m from the existing route. PGCIL has also given an undertaking that there is no overhead telecommunication lines and South East Central Railway Line within the vicinity of 8km radius.

In line with the information submitted by PGCIL, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/ diversion of the existing 400 kV S/C Korba - Bhilai Transmission Line.

Chief Engineer

To,
Sr. DGM, Powergrid
Bilaspur