



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development

Subject: - Requirement of fresh PTCC clearance for modification/diversion work of 400 kV S/C Nallagarh(PG) - Parbati Pooling Banala(PG) Transmission Line due to damage of PKTCL Line elements caused by unprecedented rainfall in Himachal Pradesh -regd.

Parbati Koldam Transmission Company Limited (PKTCL) vide letter reference no.- PrKTCL/Reg/2024-25/06 dated 17.04.2024 has requested to review the requirement of fresh PTCC clearance/ NOC in respect of diversion/ modification of existing 400 kV S/C Nallagarh(PG) - Parbati Pooling Banala (PG) Transmission Line due to damage of PKTCL Line elements caused by unprecedented rainfall in Himachal Pradesh.

PKTCL vide above letter has informed that existing 02 Nos Tower (TW-55 and TW-56) are being replaced by 01 new Tower (TW-56) resulting in a maximum lateral deviation of approx. 55 m from the existing route.

In line with the information submitted by PKTCL and PTCC approval issued vide BSNL letter No. PTCC(T)/DV-8463/HP-216 dated 30.07.2010, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/ diversion of the existing 400 kV S/C Nallagarh(PG) - Parbati Pooling Banala(PG) line.

PKTCL vide above letter also informed about erecting new tower (TW-53) in place of existing tower (TW-53) in the same alignment of 400kV S/C Koldam (NT) - Parbati Pooling Banala (PG). Since there is no change in the alignment of 400kV S/C Koldam (NT) - Parbati Pooling Banala (PG) line, therefore there is no need of fresh PTCC clearance/NOC of 400kV S/C Koldam (NT) - Parbati Pooling Banala (PG) line.

Chief Engineer

To,

Head Regulatory, PKTCL
Unit No. 101, First Floor,
Windsor, Village Kolkalyan,
off CST Road, Vidyanagari Marg,
Kalina, Santacruz (East)
Mumbai – 400098