

I/34233/2024



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development

Subject: - PTCC clearance for modification/diversion work of 400 kV D/C Navsari-Magarwada Transmission Line to facilitate construction of Vadodara-Mumbai Expressway by NHAI under Bharatmala Pariyojana-regd.

PGCIL vide email dated: 27.02.2024 has requested to review requirement of fresh PTCC clearance/ NOC in respect of diversion/ modification of existing 400 kV D/C Navsari-Magarwada Transmission Line to facilitate construction of Vadodara-Mumbai Expressway by NHAI under Bharatmala Pariyojana.

PGCIL vide above email has informed that existing 11 Nos Towers (TW-38 to TW-48) are being replaced by 12 Nos new Towers (TW-38 to TW-47, TW-47A and TW-48) resulting in a maximum lateral deviation of approximately 295 m from the existing route.

In line with the information submitted by PGCIL and PTCC approval issued vide BSNL letter No. IC/MBI/PTCC/GUJ-1862 dated 03.01.2013, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/ diversion of the existing 400 kV D/C Vadodara-Mumbai line.

Chief Engineer

To,
Chief General Manager
Powergrid,
WR-II, Navsari