

भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत प्रणाली संचार विकास प्रभाग

Power System Communication Development Division

CEA Case No.: TN-750 Induced Voltage (IV) Calculation for PTCC proposal of 33 kV D/C Feeder-No. DC 3 & 4 on RSJ pole from 220/33 kV JSW Dharapuram B Substations at Peramium Village to JSW Wind Power Unit Substations – DHP 052 (Length: 26.5 kms) S. No Reference No. **Dated** (i) JSWNEL/33kV PTCC-150 MW/DPM/DC-2 09.02.2024 JSW E-mail 28.03.2024 (ii) JSW E-mail (iii) 15.04.2024 BSNL: SR-PTCC/STN 5615/04 15.03.2024 (iv) Southern Railway: W.384/3/6/40(TN) (v) 11.03.2024

The PTCC proposal submitted vide reference (i) and (iii) has been examined. DET, PTCC (SZ), BSNL vide reference (iv) and Southern Railway vide reference (v) has issued their No Objection certificate (NOC) for charging of the line.

EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance, D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220/33 kV JSW	83.33	20	0.625	2338	1519	65	21
Dharapuram B							
Substations at							
Peramium							
Village							
33/0.69 kV	14.7	10.25	0.412	130	81	NA	NA
Wind Power unit							
substation							

As per the details submitted by BSNL vide reference (iv) above, no telephone exchanges are falling in the EPR zone of the proposed substation.

Telecommunication details from DG Signals, MoD are awaited however, vide reference (ii) above, M/s JSWNEL have informed that all construction related work of the transmission line has completed and the line is awaiting charging due to want of PTCC approval. So as to charge the subject cited transmission line as per schedule, M/s JSWNEL has requested for issuance of provisional PTCC clearance and has submitted an undertaking that in case of any impact on telecom asset/ personnel of Defense due to charging of this transmission line, JSWNEL shall take all remedial action.

Taking above into consideration, necessary action for issuance of provisional PTCC route approval may be taken under intimation to this office. LF induction on telecommunication circuits of Defense, will be communicated after the receipt of details from DG Signals, MoD.

Encl.: As above

Chief Engineer

To,

1.	Divisional	O/o Chief General Manager,	
	Engineer (PTCC),	Core Network Transmission- South,	
	Southern Zone	No.11, Link Road, Ganapathy Colony,	
		Guindy Industrial Estate, Guindy,	
		Chennai.600 032.	
	Director General	General Staff Branch, Integrated HQ,	With a request to
	of Signals	MoD (army), Sena Bhawan, DHQ,	provide details of
		PO, New Delhi- 110 105	Telecom assets/
2.			NOC at the earliest
			for IV calculation
			and issuance of
			final RAC.
3.	M/s JSW Neo	JSW Centre, Bandra Kurla Complex, bandra	For information
٥.	Energy Limited	(East), Mumbai – 400 051	