

भारत सरकार

#### Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत प्रणाली संचार विकास प्रभाग Power System Communication Development Division

\*\*\*\*\*\*

CEA Case No. : KNK-1066					
Induced Voltage (IV) Calculation for PTCC proposal of 220 kV S/C line on Double circuit and multi-circuit tower from proposed 220/33 kV 300 MW, Hire Mannapur, Koppal PSS of M/s Green Infra Wind Energy Ltd. to 400/220 kV Gadag (PG) (Length: 54.169 kms)					
S. No	Reference No.	Dated			
(i)	GIWEL/HMP-GLG/300MW/PTCC-1	18.01.2024			
(ii)	BSNL: SR-PTCC/SKT 5889/2	10.06.2024			
(iii)	South Western Railway: SG/SWR/PTCC/KNK1066/2718	14.05.2024			
(iv)	Defense: B/46937/Sigs 7(b)/3862	12.06.2024			

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on communication circuits of BSNL and South Western Railway with respect to details furnished vide above reference (ii) and (iii) respectively have been computed. The voltage likely to be induced on paralleling communication circuits of BSNL and South Western Railway under Single Line to Ground fault condition are enclosed at Annexure-I and Annexure-II respectively. The screening factors as applicable have been considered.

DG Signals, MoD vide reference (iv) above has given their NOC for charging the line.

Name of the	Half	Fault	Resistance	d (mts)	d (mts)	d (mts)	d (mts) at
proposed SS	Diagonal	Current,	of earthmat,	at 430	at 650	at 7 kV	10 kV
	Distance,	I (kA)	R (Ohms)	V	V		
	D/2 (mts)						
220/33 kV 300	86.66	28	0.2	1042	660	NA	NA
MW, Hire							
Mannapur,							
Koppal PSS of							
M/s GIWEL							
400/220 kV	164.45	35	0.114	1361	845	NA	NA
Gadag (PG) S/s							

EPR Zones for proposed substations are mentioned below.

As per details submitted by BSNL vide above reference (ii), No Telephone Exchange of BSNL are falling in the EPR zone.

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office.

Encl.: As above

#### **Chief Engineer**

η	Co.
1	L U .

1.	Divisional Engineer	O/o CGM, QA & Inspection circle, 2 <sup>nd</sup>	
	(PTCC)	Floor, Sanchar complex, WMS compound,	
		Jayanagar, 5 <sup>th</sup> block, 9 <sup>th</sup> main, 47 <sup>th</sup> cross,	
		Bengaluru- 560 041	
2.	GM (S&T), South	South Western Railway Headquarter, Rail	
	Western Railway	Soudha, Hubbali – 580 023	
3.	M/s Green Infra	5 <sup>th</sup> Floor, Tower C, Building No. 8, DLF	Copy for information
5.	Wind Energy Limited	Cybercity, Gurugram – 122 002	Copy for information

### ANNEXURE-I

Name of circuit to	se No.: KNK-1066 T <b>the Power line</b> : 220 kV S/C line on Double circu wer from proposed 220/33 kV 300 MW, Hire Mann I/s Green Infra Wind Energy Ltd. to 400/220 kV Ga	apur, Koppal	Total Length	: 1 cm= 500 m : 54.169 km 25000 Ohm-cm	
S.No.	Telecom. Details	Length of Parallelis m in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
	BSNL: SR-PTCC/SKT	5889/2 Dated:	10.06.2024	I I	
1	Kushtagi TE to K1	IV less than 430 V			
2	Kushtagi TE to K2	IV less than 430 V			
3	Kushtagi TE to K3	IV less than 430 V			
4	Kushtagi TE to K4	IV less than 430 V			
5	Kushtagi TE to K5	IV less than 430 V			

#### ANNEXURE-II

CEA Case No.: KNK-1066Map Scale : 1 cm= 500 mName of the Power line: 220 kV S/C line on Double circuit and multi- circuit tower from proposed 220/33 kV 300 MW, Hire Mannapur, Koppal PSS of M/s Green Infra Wind Energy Ltd. to 400/220 kV Gadag (PG)Map Scale : 1 cm= 500 mS.R. Value : 25000 Ohm-cm							
S.No.	Telecom. Details	Length of Parallelis m in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.		
	South Western Railway: SG/SWR/PTCC/KNK1066/2718 Dated: 14.05.2024						
1	LNBI - KUSTAGI	7.1	0.000911	18661	17		

l/41313/2024

Directorate General of Signals Signals - 7 General Staff Branch Integrated HQ of MoD, (Army) DHQ PO, New Delhi – 110011

KNK-1066

# B/46937/Sigs 7(b)/3862

Jun 2024

Green Infra Wind Energy Limited Regd Off: 5<sup>th</sup> Floor, Tower C, Building No. 8 DLF Cybercity, Gurugram-122002, Haryana, India

## PTCC PROPOSAL FOR THE "PROPOSED CONSTRUCTION OF 220KV OH S/C LINE ON D/C TOWERS WITH AL-59 MOOSE CONDUCTOR FROM THE PROPOSED M/S. GREEN INFRA WIND ENERGY LTD, GURUGRAM'S 220/33KV 300MW WIND ENERGY PROJECT PSS SITUATED AT HIRE MANNAPUR OF KOPPALA DISTRUCT TO UNDER-CONSTRUCTION M/S POWER GRUID CORPORATION OF INDIA LTD'S 400/220KV GADAG PS (ISTS SUB-STATION) SITUATED NER GULAGULI OF GADAG DISTRICT".

1. Refer your letter dt 29 Mar 2024 (copy att).

2. **No Objection Certificate (NOC) is accorded** based on inputs provided as per Map sheet received vide your letter mentioned above.

3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(Puneet Lakhanpal) Lieutenant Colonel

General Staff Officer Grade 1 (Communication) for Additional Director General (Telecommunication)

Enclosures : As above Copy to :-

Chief Engineer, PSCD Division Central Electricity Authority Room No 702 (North Wing) Sewa Bhawan, R.K. Puram, Sector-1 New Delhi-110066

The DET(PTCC), Northern Zone Bharat Sanchar Nigam Limited O/o PGM (North), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath New Delhi-110001

Central Electricity Authority PCD Division n

Aush

for information