



सत्यमेव जयते

**भारत सरकार**  
**Government of India**  
**विद्युत मंत्रालय**  
**Ministry of Power**  
**केन्द्रीय विद्युत प्राधिकरण**  
**Central Electricity Authority**  
**विद्युत प्रणाली संचार विकास प्रभाग**  
**Power System Communication Development Division**  
**\*\*\*\*\***

<b>CEA Case No. : KNK-1086</b>		
<b>Induced Voltage (IV) Calculation for PTCC proposal of 33 kV (partially S/C and partially D/C) Feeder-07 on RSJ Pole with AL-59 Dog, Panther &amp; ECO Panther conductor from 220/33 kV Wind Power Substation of M/s Serentica Renewables India 3 Private Limited, Jakkali Village to 33 kV Wind Power Unit Substation Location NGL-88. (Length: 14.883 km).</b>		
<b>S. No</b>	<b>Reference No.</b>	<b>Dated</b>
(i)	SRIPL-3/33kV/PTCC/F7	19.02.2024
(ii)	BSNL: SR-PTCC/SKT5764/2	25.04.2024
(iii)	South Western Railway: SG/SWR/PTCC/KNK1086/2698	28.06.2024
(iv)	Defense: B/46937/Sigs 7(b)/3812	04.06.2024

The PTCC proposal submitted vide reference (i) has been examined. DET (PTCC), SZ, BSNL vide reference (ii), PCSTE, South Western Railway vide reference (iii) and DG Signals, MoD vide reference (iv) has given their NOC for charging the line.

EPR Zones for proposed substations are mentioned below.

Name of the proposed SS	Half Diagonal Distance, D/2 (mts)	Fault Current, I (kA)	Resistance of earthmat, R (Ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7 kV	d (mts) at 10 kV
220/33 kV 270 MW, PSS of M/s SRI3PL at Jakkali Village	97.51	45.5	0.036	274	148	NA	NA
33 kV Wind Power Unit Substation Location NGL-88	4.05	19.1	0.34	57	36	NA	NA

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office. This issues with the approval of Chief Engineer.

Encl.: As above

**Deputy Director**

**To,**

1.	Divisional Engineer (PTCC)	O/o CGM, QA & Inspection circle, 2 <sup>nd</sup> Floor, Sanchar complex, WMS compound, Jayanagar, 5 <sup>th</sup> block, 9 <sup>th</sup> main, 47 <sup>th</sup> cross, Bengaluru- 560 041	
2.	M/s Serentica Renewables India 3 Private Limited	DLF Cyber Park, Block B, 9 <sup>th</sup> Floor, Udyog Vihar, Phase III, Sector 20, Gurugram	Copy for information

Signals 7

General Staff Branch

KNK-1086

Integrated HQ of MoD, (Army)

DHQ PO, New Delhi – 110011

B/46937/Sigs 7(b)/3813

04 Jun 2024

Serentica Renewables India 3 Pvt Ltd.

Regd Off: DLF Cyber Park, Block B, 9<sup>th</sup> Floor,

Udyog Vihar, Ph-III, Sector-20 Gurugram (Haryana)-122008

**PTCC PROPOSAL FOR CONSTRUCTION OF PROPOSED 33KV OVER  
HEADLINE FOR FEEDER NO. 7 FROM PROPOSED of M/S SERENTICA  
RENEWABLES INDIA 3 PVT LTD 270 MW, NGL-88 TO M/S SERENTICA  
RENEWABLES INDIA 3 PVT LTD WIND POWER POOLING SUBSTATION AT  
JAKKALI VILLAGE, GADAG DISTRICT, KARNATAKA**

1. Refer your letter No SRIPL-3/33KV/PTCC/F7 dt 06 Mar 2024 (copy att).
2. **No Objection Certificate (NOC) is accorded** based on inputs provided as per Map sheets received vide your letter mentioned above.
3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.



(Puneet Lakhanpal)

Lieutenant Colonel

General Staff Officer Grade 1 (Communication)

for Additional Director General (Telecommunication)

**Enclosures** : As above**Copy to :-**

The Divisional Engineer (PTCC)  
D Wing, 3<sup>rd</sup> Floor, Admn Bdg  
Telecom Complex,  
Juhu Tara Road,  
Santracruz West, Mumbai – 400054

Chief Engineer, PSCD Division  
Central Electricity Authority  
Room No 702 (North Wing)  
Sewa Bhawan, R.K. Puram, Sector-1  
New Delhi-110066

The DET(PTCC), Northern Zone  
Bharat Sanchar Nigam Limited  
O/o PGM (North), QA & Inspection Circle,  
D-Tax Building, Eastern Court, Janpath  
New Delhi-110001

- for information

Central Electricity Authority

PCD Division

Diary No. 669

Date: 06-06-24