

भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत प्रणाली संचार विकास प्रभाग

Power System Communication Development Division

CEA Case No.: MRA-1243			
Induced Voltage (IV) Calculation for PTCC proposal of 220 kV S/C line on D/C tower from 220/33 kV 350 MW Wind power PSS of M/s Serentica Renewables India 4 Limited at Tanduwadi village to 400/220 kV Kallam PS (Length: 13.707 kms)			
S. No	Reference No.	Dated	
(i)	SRIPL/TD/220kV/MISCELLANEOUS/01/03	13.03.2024	
(ii)	BSNL: IC/MBI/PTCC/MRA-2634/03	11.07.2024	
(iii)	Central Railway: N.153/PTCC/220kV/MAH-875	11.07.2024	
(iv)	Defense: B/46937/Sigs 7(b)/3824	04.06.2024	

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on communication circuits of BSNL with respect to details furnished vide above reference (ii) has been computed. The voltage likely to be induced on paralleling communication circuits of BSNL under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors as applicable have been considered.

GM (S&T), Central Railway vide reference (iii) and DG Signals, MoD vide reference (iv) have issued their NOC for charging the line.

EPR Zones for proposed substations are mentioned below.

Name of the proposed SS	Half Diagonal Distance,	Fault Current, I (kA)	Resistance of earthmat, R (Ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7 kV	d (mts) at 10 kV
	D/2 (mts)						
220/33 kV 350	125.25	21.5	0.478	2868	1855	59	3
MW Wind power							
PSS of M/s							
SRI4PL at							
Tanduwadi							
village							

As per the details submitted by BSNL vide above reference (ii), No Telephone exchange is falling in the EPR zone of proposed substation.

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office.

Encl.: As above

Chief Engineer

To,

1.	Divisional Engineer	QA & Inspection circle, 1 st floor, D- wing,	
	(PTCC), Western Zone	BSNL Admin Bldg., Junu Tara Road,	
	Santacruz (West), Mumbai-400054		
	M/s Serentica	DLF Cyber Park, 9th Floor, Tower-B,	
2.	Renewables India 4	Udyog Vihar, Phase-III, Sector-20,	Copy for information
	Limited	Gurugram – 122 008	

ANNEXURE-I

CEA Case No.: MRA-1243

Map Scale : 1 cm = 500 m

Total Length: 13.707 kms

Name of the Power line: 220 kV S/C line on D/C tower from 220/33 kV 350 MW Wind power PSS of M/s Serentica Renewables India 4 Limited

S.R. Value : 25000 Ohm-cm

at Tanduwadi village to 400/220 kV Kallam PS

		Length of	Mutual	Effective	I.V
		Parallelis m	Coupling	Fault current	in
S.No.	Telecom. Details	in Km.	in Ohms.	in Amps.	Volts.

BSNL: IC/MBI/PTCC/MRA-2634/03 Dated: 11.07.2024			
1	Armored 6F OF cables (Point U to Point F)	Out of parallelism	