

# भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत प्रणाली संचार विकास प्रभाग

## Power System Communication Development Division

\*\*\*\*\*

CEA Cas	A Case No.: MRA-1260			
through	uced Voltage calculation for PTCC proposal of LILO of 220 kV Mahape – Tiffil line ough UG cable at 220 kV GIS S/s of M/s STT Global Data Centres India Pvt. Ltd. ngth: 0.448 Kms) - regd.			
S. No	Reference No.	Dated		
(i)	MSETCL/CO/PS/PTCC/In/B-602/No 02176	03.04.2024		
(ii)	BSNL: IC/MBI/PTCC/MRA-2627/03	26.06.2024		
(iii)	Central Railway: N.153/PTCC/220kV/MAH-873	21.06.2024		
(iv)	Defense: B/46937/Sigs 7(b)/3865	04.06.2024		

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on communication circuits of MTNL and Central Railway with respect to details furnished vide above reference (ii) and (iii) respectively have been computed. The voltage likely to be induced on paralleling communication cables of MTNL and Central Railway under Single Line to Ground fault condition are enclosed at Annexure-I and Annexure-II respectively. The screening factors as applicable have been considered. DG Signals, MoD have issued No Objection Certificate (NOC) for charging of the line vide reference (iv) (Anenxure-III).

EPR zone for the proposed substation is mentioned below:

Name of the proposed Substation	Half diagonal distance , D/2 (mts)	Fault Current I (KA)	Resistance of Earth Mat, R (ohms)	d (mts) at 430 V	d (mts) at 650 V	d (mts) at 7kV	d (mts) at 10kV
220 kV GIS S/s of M/s STT Global Data Centres India Pvt. Ltd.	12.6	30.21	0.93	811	532	38	23

As per the details submitted by BSNL vide reference (ii) above, **EL Zone RSU Telephone** Exchange of MTNL is falling in the contour of 430 V EPR zone of the proposed substation.

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken under intimation to this office.

**Chief Engineer** 

## To,

1.	Divisional	QA & Inspection circle,	
	Engineer (PTCC),	1st floor, D- wing, BSNL Admin Bldg.,	
	Western Zone	Junu Tara Road, Santacruz (West),	
		Mumbai-400054	
2.	GM (S&T)	Central Railway, Office of PCSTE, 3rd Floor,	
		Annex building, CSMT Mumbai – 400 001	
	Chief Engineer	MahaTransco C.O., 'Prakashganga'	
3.	(Projects Schemes	Plot No C-19, E- Block, BKC, Bandra(E),	Copy for information
	Deptt.)	Mumbai-400051	

### **ANNEXURE-I**

CEA Case No.: MRA-1260

Name of the Power line: LILO of 220 kV Mahape – Tiffil line through UG cable at 220 kV GIS S/s of M/s STT Global Data Centres India Pvt.

Map Scale : 1 cm = 500 m

**Total Length:** 0.443 km

Ltd.			S.R. Value: 10000 Ohm-cm				
.No.	Telecom. Details	Length of Parallelis m in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts		
	BSNL: IC/MBI/PTC	C/MRA-2627/03 <b>Date</b>	e: 26.06.2024				
1	Cables from Kharghar TE		Out of parallelism				
2	Cables from Nerul TE		Out of parallelism				
3	Cables from APMC TE		Out of parallelism				
4	Cables from EL Zone RSU TE		IV less than 430 V				
5	Cables from KKR TE		IV less than 430 V				
6	Cables from MBP TE		IV less than 430 V				
7	Cables from Rabale TE		Out of parallelism				
8	Cables from Sanpada TE		Out of parallelism				
9	Cables from Turbhe TE		Out of parallelism				
10	Cables from Vashi TE		Out of parallelism				
11	Cables from Vashi Rly Stn TE		Out of parallelism				
12	Cables from VSI Sec 7 TE		Out of parallelism				
13	Cables from Airoli TE		Out of parallelism				
14	Cables from Kausa TE		Out of parallelism				
15	Cables from NMUM TE		Out of parallelism				
16	Cables from Riverwood TE		Out of parallelism				

SNPD-VSH

4

### **ANNEXURE-II**

Out of parallelism

CEA Case No.: MRA-1260 Map Scale : 1 cm = 500 mName of the Power line: LILO of 220 kV Mahape - Tiffil line through **Total Length:** 0.443 km UG cable at 220 kV GIS S/s of M/s STT Global Data Centres India Pvt. **S.R. Value**: 10000 Ohm-cm Ltd. Length of **Effective** Mutual I.V**Parallelis Fault** Coupling current m in Telecom. Details S.No. in Km. in Ohms. in Amps. Volts. Central Railway: N.153/PTCC/220kV/MAH-873 Date: 21.06.2024 AIRL - TUH 0.25 0.000764 21424 17 1 TUH-JNJ-NEU Out of parallelism 2 TUH-SNPD Out of parallelism 3