



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development

Subject: - PTCC clearance for modification/diversion work of 400 kV S/C Moradabad-Hapur Transmission Line due to construction of six lane Hapur Bypass to Moradabad Section of NH24 by M/s NHAI,PIU Moradabad -regd.

PGCIL vide letter reference no.- NR-I/Dadri/TLM/div/MBD-HPR/PTCC dated 05.07.2024 and E-Mail dated 06.07.2024 has requested to review requirement of fresh PTCC clearance/ NOC in respect of diversion/ modification of existing 400 kV S/C Moradabad-Hapur Transmission Line due to construction of six lane Hapur Bypass to Moradabad Section of NH24 by M/s NHAI,PIU Moradabad.

PGCIL vide above letter has informed that existing 02 Nos Tower (TW-172 ad TW-173) are dismantled and 02 Nos new Towers (TW-172 and TW-173) are erected resulting in maximum lateral deviation of approximately 90m.

In line with the information submitted by PGCIL, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/ diversion of the existing 400 kV S/C Moradabad-Hapur Transmission Line.

Chief Engineer

To,
DGM (TL)
HVDC Terminal Dadri, Vidyut Nagar
Gautam Budh Nagar (UP)-201008
PGCIL