



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत प्रणाली संचार विकास प्रभाग
Power System Communication Development

Subject: - PTCC clearance for modification/diversion work of 400 kV D/C Nigrie - Satna Transmission Line due to construction of Rewa – Sidhi new broad gauge rail line-regd.

Jaypee Nigrie Super Thermal Power Plant (JNSTPP) vide email dated 12.06.2024 has requested to review requirement of fresh PTCC clearance/ NOC in respect of diversion/ modification of existing 400 kV D/C Nigrie - Satna Transmission Line due to construction of new Rewa – Sidhi broad gauge rail line on the request of SSE WCR Rewa letter no. - Dy. CE/C/Rewa/Shifting/HT Line/02 dated- 15.06.2023.

JNSTPP vide above email has informed that existing 03 Towers (TW-142, TW-143 and TW-144) are dismantled and 04 new towers are erected (TW-142R, TW-143R, TW-144R and TW-145AR) resulting in a maximum lateral deviation of approx. 108 m from the existing route.

In line with the information submitted by JNSTPP and PTCC approval issued vide BSNL letter No. IC/MBI/PTCC/MP-350 dated 26.03.2013, received reference has been examined and it is found that fresh PTCC approval is not required due to proposed modification/ diversion of the existing 400 kV D/C Nigrie - Satna Transmission Line.

Chief Engineer

To,
Vice-President (Electrical and Instrumentation)
2x660 MW Jaypee Nigrie Super Thermal Power Plant
Jaiprakash Power Ventures Limited
VPO Nigrie Tehsil-Sarai Dist Singrauli (MP)
Email: navin.tinguria@jalindia.co.in

